

Functional Bonding and Shielding of PROFIBUS and PROFINET

Guideline for PROFIBUS and PROFINET

Version: 3.1 – Date: Sep. 2022

Order No.: 8.102

File name: Earthing-Shielding_8102_V31_Sep22.docx

Prepared by PI Working Group PG3 "Installation Guide PB&PN" in Committee CB "PROFINET".

The attention of adopters is directed to the possibility that compliance with or adoption of PI (PROFIBUS International) specifications may require use of an invention covered by patent rights. PI shall not be responsible for identifying patents for which a license may be required by any PI specification, or for conducting legal inquiries into the legal validity or scope of those patents that are brought to its attention. PI specifications are prospective and advisory only. Prospective users are responsible for protecting themselves against liability for infringement of patents.

NOTICE:

The information contained in this document is subject to change without notice. The material in this document details a PI specification in accordance with the license and notices set forth on this page. This document does not represent a commitment to implement any portion of this specification in any company's products.

WHILE THE INFORMATION IN THIS PUBLICATION IS BELIEVED TO BE ACCURATE, PI MAKES NO WARRANTY OF ANY KIND, EXPRESS OR IMPLIED, WITH REGARD TO THIS MATERIAL INCLUDING, BUT NOT LIMITED TO ANY WARRANTY OF TITLE OR OWNERSHIP, IMPLIED WARRANTY OF MERCHANTABILITY OR WARRANTY OF FITNESS FOR PARTICULAR PURPOSE OR USE.

In no event shall PI be liable for errors contained herein or for indirect, incidental, special, consequential, reliance or cover damages, including loss of profits, revenue, data or use, incurred by any user or any third party. Compliance with this specification does not absolve manufacturers of PROFIBUS or PROFINET equipment, from the requirements of safety and regulatory agencies (TÜV, BIA, UL, CSA, FCC, IEC, etc.).

PROFIBUS® and PROFINET® logos are registered trade marks. The use is restricted to members of PROFIBUS&PROFINEWT International. More detailed terms for the use can be found on the web page <http://www.profibus.com/download/presentations-logos/>.

Publisher:
PROFIBUS Nutzerorganisation e.V.
Haid-und-Neu-Str. 7
76131 Karlsruhe
Germany
Phone: +49 721 / 986 197 0
Fax: +49 721 / 986 197 11
E-mail: info@profibus.com
Web site: www.profibus.com

© No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

Revision log

Version	Datum	Editor	Changes /History
2.1	20.07.2020	Niemann	Initial version with extensions for Process Industry
2.2	06.09.2020	Niemann	Final Version: Changes accepted, Review comments removed. Additional safety hind for areas with explosive atmosphere added
2.3	07.09.2020	Niemann	Disclaimer updated to recent version. Typo corrected in chapter 3.3
2.4	14.10.2020	Niemann	Clean up of minor errors
2.6	16.02.2021	Niemann	Chapter about shield currents added
2.8	04.03.2022	Niemann	APL related information added
3.0	31.07.2022	Niemann	Alignment between de and en version. Page breaks adapted.
3.1	23.09.2022	Niemann	Preparation for Release

Disclaimer of Liability

PROFIBUS Nutzerorganisation e.V. (PROFIBUS user organization, hereinafter in this disclaimer referred to as “PNO”) has taken utmost care in the preparation of this document and compiled all information to the best of its knowledge. This document is nevertheless based on present knowledge, is of an informative character and is provided on the basis of liability exclusion. This document may be subject to change, enhancement or correction in the future without any expressive reference.

This document has no normative character. It may be useful in certain operating environments, in certain technical constellations or when used in certain countries to deviate from the given recommendations for action. In this case, the installer and operator of the installation should weigh up the advantages and disadvantages of the recommendations made in the specific application and, if deemed appropriate, decide on the implementation of a different solution if necessary.

The user may not distribute, rent or make available the Information in any other way to any third party at any time.

Any liability for defects as to quality or title of the information, especially in relation to the correctness or absence of defects or the absence of claims or third-party rights or in relation to completeness and/or fitness for purpose are excluded, except for cases involving gross negligence, willful misconduct or fraudulent concealment of a defect. Any further liability is excluded unless required by law, e.g. in cases of personal injury or death, willful misconduct, gross negligence, or in case of breach of fundamental contractual obligations.

Management Summary

This document deals with the shielding of PROFIBUS/PROFINET networks and with equipotential bonding in the corresponding plants. The document describes an optimized structure for process automation systems intended to reduce the effects of electromagnetic interference (EMI) and disturbances by using equipotential bonding systems. In a tiered approach, the readers are first made familiar with the technical basics of electromagnetic compatibility (EMC), equipotential bonding and shielding. In chapter 4, six recommendations for action are developed by using a plant example. Chapter 5 also deals with additional requirements of the process industry.

The recommendations for action for the manufacturing industry are listed in the following table.

M1	Provide both protective equipotential bonding and functional equipotential bonding through a common bonding network (CBN).
M2	Preferably use a 230/400 V power supply using a TN-S system.
M3	Design combined equipotential bonding system (Common Bonding Network CBN) as finely meshed as possible (MESH-BN).
M4	Provide a connection of the PROFIBUS/PROFINET cable shields through the housings of the connectors and through the housings of the devices and thus to the common bonding network (CBN) at each cable end with big contact surfaces (low impedance).
M5	<ul style="list-style-type: none"> • Use shielded motor cables in accordance with the manufacturer specifications and provide for large-surface connection of the shield at each end to the common bonding network (CBN) with low impedance. • Connect the motor to the common bonding network (CBN). • If unshielded motor cables are used, provide filters at the inverter output. • If not excluded by the manufacturer of the frequency converter, preferably use symmetrical shielded three-wire motor cables with separate protective conductor. • The instructions of the frequency inverter manufacturer should always be checked and followed.
M6	<ul style="list-style-type: none"> • Multiple connections of 24-V-Supply-Circuits to the common bonding network (CBN) have to be avoided. • In order to keep the cables between the power supply unit and the consumer as short as possible, it is recommended to use several smaller power supplies rather than a single big one.

The recommendations for action for the process industry are listed in the following table.

P1	Provide both protective equipotential bonding and functional equipotential bonding through a common bonding network (CBN).
P2	Preferably use a 230/400 V power supply using a TN-S system. Use a TN-S system in the areas with explosive atmosphere in any case.
P3	<ul style="list-style-type: none"> • Design combined equipotential bonding system (Common Bonding Network CBN) as finely meshed as possible (MESH-BN). • Provide Potential separation or a continuous CBN between hall boundaries. • Provide continuous CBN inside and outside the area with explosive atmosphere. • In areas with explosive atmosphere, safely connect electrical and external conductive parts with CBN.
P4	<ul style="list-style-type: none"> • Provide a connection of the PROFIBUS/PROFINET cable shields through the housings of the connectors and through the housings of the devices and thus to the common bonding network (CBN) at each cable end with big contact surfaces (low impedance). • In areas with explosive atmosphere, if equipotential bonding is not ensured to a high degree, connect shield at one end or both ends with capacitor (max. 10 nF) at one end.
P5	<ul style="list-style-type: none"> • Use shielded motor cables and provide for large-surface connection of the shield at each end to the common bonding network (CBN) with low impedance, ensure proper shield connection in the area with explosive atmosphere. • If unshielded motor cables are used, provide filters at the inverter output. See also the recommendations of NAMUR Guideline NE 108. • Connect the motor to the Common Bonding Network (CBN). See also chapter 4.3

	<ul style="list-style-type: none">• If not excluded by the manufacturer of the frequency converter, preferably use symmetrical shielded three-wire motor cables with separate protective conductor. See also chapter 4.5• The instructions of the frequency inverter manufacturer should always be checked and followed.
P6	<ul style="list-style-type: none">• Multiple connections of 24 V circuits with the Common Bonding Network (CBN) have to be avoided and are not permitted in the area with explosive atmosphere.• In order to keep the cables between the power supply unit and the consumer as short as possible, it is recommended to use several smaller power supplies rather than a single big one. See also chapter 4.6

Content

Revision log	3
Disclaimer of Liability	4
Management Summary	5
1 Introduction	16
1.1 Introduction to the subject/problem	16
1.2 Objective of this document	18
2 EMI fundamentals	19
2.1 Couplings	20
2.1.1 Conductive coupling	21
2.1.2 Capacitive coupling	24
2.1.3 Inductive coupling	25
2.1.4 Radiated coupling	25
2.2 Electrostatic discharge	26
2.3 Typical sources of disturbance in automation systems	27
3 Fundamentals of equipotential bonding and shielding	28
3.1 Cable shielding	28
3.1.1 Passive shielding	28
3.1.2 Active shielding	29
3.2 Equipotential bonding	31
3.2.1 Protective earth conductor (PE)	31
3.2.2 Protective equipotential bonding	31
3.2.3 Functional equipotential bonding (FE)	33
4 Recommendations for the design of PROFIBUS and PROFINET networks with little disturbance ...	34
4.1 Combination of protective and functional equipotential bonding systems	36
4.1.1 Problem description	36
4.1.2 Solutions from standards and specialist literature	37
4.1.3 Recommendations for PROFIBUS and PROFINET	37
4.2 Implementation of 230/400V mains supply	38
4.2.1 Problem descriptions	40
4.2.1.1 Mains supply network as TN-C system	40
4.2.1.2 Mains supply network as TN-C-S system	44
4.2.1.3 Mains supply network as TN-S system	47
4.2.2 Descriptions in the relevant standards and specialist literature	51
4.2.3 Recommendations for PROFIBUS and PROFINET	52
4.3 Equipotential bonding system	54
4.3.1 Problem description	55

4.3.2	<i>Solutions from standards and technical literature.....</i>	62
4.3.3	<i>Recommendations for PROFIBUS and PROFINET.....</i>	65
4.4	Connection of PROFIBUS/PROFINET cable shields.....	74
4.4.1	<i>Problem description with solutions from standards and technical literature.....</i>	74
4.4.2	<i>Recommendations for PROFIBUS and PROFINET.....</i>	77
4.5	Motor lines	78
4.5.1	<i>Problem description</i>	78
4.5.1.1	Capacitive coupling in motor lines	79
4.5.1.2	Inductive coupling in motor lines	80
4.5.2	<i>Solutions from standards and specialist literature</i>	82
4.5.3	<i>Recommendations for PROFIBUS and PROFINET.....</i>	85
4.6	Connecting the negative pole of 24 V power supply to the CBN	87
4.6.1	<i>Problem description</i>	89
4.6.1.1	Connection of 24 V power supply circuits to CBN, scenario 1	90
4.6.1.2	Connection of 24 V power supply circuits to CBN, scenario 2	91
4.6.1.3	Connection of 24 V power supply circuits to the CBN, scenario 3	92
4.6.2	<i>Solutions from standards and technical literature.....</i>	92
4.6.3	<i>Recommendations for PROFIBUS and PROFINET.....</i>	93
5	Recommendations for the process industry	95
5.1	Connection of protective and functional equipotential bonding	96
5.2	Structure of the 230V/400V mains supply	97
5.3	Equipotential bonding system.....	97
5.4	Connection of the PROFIBUS and PROFINET cable shields.....	101
5.5	Motor cables	105
5.6	Connection of the negative pole of a 24 V supply to the CBN.....	106
6	Summary of the recommendations for the design of PROFIBUS and PROFINET networks with little disturbance	107
6.1	Manufacturing Industry	109
6.2	Process Industry	110
7	Shield Current Measurement.....	112
7.1	Importance of shield currents	112
7.2	Shield current measurement	114
7.3	Remedial measures for excessive shield currents	115
7.4	Meaning of the loop impedance	116
7.5	Loop impedance measurement	117
7.6	Remedy for excessive loop impedance	118
8	Suggestions for possible acceptance tests	119

9	Literature	123
10	Appendix A1 Current Clamp Recommendations	126

List of figures

Figure 1.1: Evaluation of the assignments of the Field Service Excellence WG from 2009 to 2014 [GÖH2015]	17
Figure 2.1: EMC interfaces of a device according to [RUD2011].....	19
Figure 2.2: Coupling lines	20
Figure 2.3: Conductive coupling in equipotential bonding system 1	21
Figure 2.4: Conductive coupling in equipotential bonding system 2	22
Figure 2.5: Conductive coupling in equipotential bonding system 3	22
Figure 2.6: Conductive coupling in equipotential bonding system 4	23
Figure 2.7: Capacitive coupling	24
Figure 2.8: Inductive coupling.....	25
Figure 3.1: Repetition of capacitive coupling	29
Figure 3.2: Active shielding with one-sided connection to the common bonding network (CBN)	29
Figure 3.3: Induction in the cable shield	30
Figure 4.1: Plant example from the manufacturing industry	35
Figure 4.2: Network systems	38
Figure 4.3: TN-C-S system as network system	39
Figure 4.4: TN-C system.....	40
Figure 4.5: TN-C system with load	41
Figure 4.6: TN-C system with load and current flow	41
Figure 4.7: TN-C system with several connections to the equipotential bonding system	42
Figure 4.8: TN-C system with multiple earthing, load and current flow	43
Figure 4.9: TN-C-S system	44
Figure 4.10: Current flow in a TN-C-S system	45
Figure 4.11: Current flow in a TN-C-S system with multiple earthing	45

Figure 4.12: Current flow in a TN-C-S system with targeted multiple earthing	46
Figure 4.13: TN-S system.....	47
Figure 4.14: TN-S system with load.....	48
Figure 4.15: TN-S system with load and current flow	49
Figure 4.16: TN-S system with two PEN bridges.....	49
Figure 4.17: : TN-S system with two PEN bridges, load and current flow.....	50
Figure 4.18: Ideal TN-S system	53
Figure 4.19: Star-type equipotential bonding	54
Figure 4.20: Tree-type equipotential bonding	55
Figure 4.21: Equipotential bonding system in star topology with PROFIBUS lines.....	56
Figure 4.22: Equipotential bonding system in star topology with PROFIBUS lines 2.....	57
Figure 4.23: Equipotential bonding system in star topology with PROFIBUS lines 3.....	57
Figure 4.24: Meshes in an equipotential bonding system with star topology	59
Figure 4.25: PROFIBUS lines and equipotential bonding lines.....	60
Figure 4.26: Meshes with PROFIBUS lines and equipotential bonding lines.....	61
Figure 4.27: Equipotential bonding systems referring to [DIN-EN 50310]	62
Figure 4.28: Meshed equipotential bonding system	63
Figure 4.29: Improved equipotential bonding systems referring to [DIN-EN 50310].....	64
Figure 4.30: Meshed equipotential bonding.....	65
Figure 4.31: Ring lines in meshed equipotential bonding system	66
Figure 4.32: Stubs of the meshed equipotential bonding system	67
Figure 4.33: Connection blocks (WPAK clamps)	68
Figure 4.34: Stubs from ring line to devices (Picture Weidmüller)	68
Figure 4.35: Meshed equipotential bonding via the foundation earth electrode.....	69
Figure 4.36: Earthing points [DEH2016]	70
Figure 4.37: Mesh formed by a cable shield in a meshed equipotential bonding system	71

Figure 4.38: Many small meshes in a meshed equipotential bonding system	72
Figure 4.39: Example of electrostatic discharge	73
Figure 4.40: Connection of the cable shield to CBN close to a PROFINET device	75
Figure 4.41: Multiple connection of the cable shield of a PROFIBUS line with the CBN	76
Figure 4.42: Additional connection of the cable shield [NIE2017]	76
Figure 4.43: Shielded motor line	78
Figure 4.44: Capacitive coupling in shielded motor lines	79
Figure 4.45: Magnetic field lines in a motor line	80
Figure 4.46: Inductive coupling between L1 and L2	80
Figure 4.47: Inductive coupling in a motor line	81
Figure 4.48: Typical installation of a frequency converter from [DAN2015]	83
Figure 4.49: Drive with low voltage power supply from [ABB2005]	84
Figure 4.50: Symmetrical motor lines as recommended by [SIE2014]	85
Figure 4.51: 24 V power supply in a manufacturing plant	87
Figure 4.52: Simplified representation of a 24 V power supply circuit	88
Figure 4.53: Multiple connections to CBN in a 24 V power supply circuit	89
Figure 4.54: Connection 24 V power supply circuits to CBN, scenario 1	90
Figure 4.55: Connection of 24 V power supply circuits to CBN, scenario 2	91
Figure 4.56: Connection of 24 V power supply circuits to CBN, scenario 3	92
Figure 4.57: Optimal earthing of 24 V power supply circuits	94
Figure 5.1: Plant example from the process industry	96
Figure 5.2: Copper cable between plant sections	98
Figure 5.3: Fiber-Optic cable between plant sections	99
Figure 5.4: Continuous meshed CBN between plant sections	99
Figure 5.5: Grounding of cable shield on both sides in areas with explosive atmosphere for PROFIBUS PA	101

Figure 5.6: Grounding of cable shield on both sides with capacitor in areas with explosive atmosphere.....	102
Figure 5.7: Ignition hazard due to insulation faults and poor equipotential bonding	103
Figure 7.1: Current through shield loop, required for active shielding effect against magnetic fields.....	113
Figure 7.2: Distribution of current between equipotential bonding conductor and signal line	113
Figure 7.3: Measurement of shield current with current clamp	114
Figure 7.4: Loop impedance measurement	117

List of tables

Table 2.1: Frequency spectrum of potential sources of disturbance from [SCH2008] ...	27
Table 5.1: Connection possibilities of cable shield and CBN in areas with explosive atmosphere.....	104
Table 7.1: Measures to be taken in case of excessive shield currents (guide values).	115
Table 7.2: Further remedial measures to lower the currents in equipotential bonding.	116
Table 7.3: Remedial measures for excessive loop impedance.....	118
Table 8.1: Suggestions for possible acceptance tests	120

1 Introduction

At first this document deals with functional bonding and shielding of PROFIBUS/PROFINET networks and with equipotential bonding in plants of the manufacturing industry. Chapter 5 also deals with additional requirements of the process industry. The aim is to provide users and designers with a standardized procedure in order to achieve a disturbance-free structure for automation systems. In addition to the procedures described in this document, the applicable standards and guidelines for electrical safety must be observed. The illustrations and symbols used in this document may differ from those in the relevant standards and guidelines.

1.1 Introduction to the subject/problem

An analysis conducted by the “Field Service Excellence” work group (WG) of the PROFIBUS User Organization in the years 2009 to 2014 has revealed the error causes that were most frequently identified during PROFIBUS and PROFINET service operations. It should be mentioned in this context that the service assignments of the WG are mainly troubleshooting activities that go far beyond the usual range of requirements on electrically skilled service and maintenance personnel.




Figure 1.1: Evaluation of the assignments of the Field Service Excellence WG from 2009 to 2014 [GÖH2015]

Figure 1.1 clearly shows that EMC errors resulting from electromagnetic incompatibility have caused more than half of the service assignments of the companies joining the Field Service Excellence work group. These EMC errors are mainly problems that manifest themselves through impermissibly high shield currents, inductances without interference suppression and loads of the equipotential bonding systems.

1.2 Objective of this document

The objective of this document is to provide a basis for the functional bonding and shielding of PROFIBUS and PROFINET bus systems. The focus is not on the design of PROFIBUS/PROFINET devices, but on their correct connection and on the cabling of plants in order to prevent field-based disturbances and disturbances through the equipotential bonding system.

In a tiered approach, the readers are first made familiar with the technical basics of electromagnetic compatibility. Then the document imparts the fundamentals of functional bonding and shielding in process automation systems. In the next step, six recommendations for actions allowing to implement PROFIBUS and PROFINET networks with only little disturbance are given. A list of acceptance criteria completes this document.

The planning, installation and commissioning as well as EMC considerations of Ethernet-APL networks is described in the Ethernet-APL Engineering Guideline [APL2021] Therefore, Ethernet APL is not covered in this document.

2 EMI fundamentals

Electromagnetic interference (EMI) is a phenomenon where devices are affected by electric and magnetic fields. All electrical devices generate magnetic and electric fields, which may disturb the function of other devices. For example, EMI causes potential problems and data loss in communication lines. The counterpart of EMI is electromagnetic compatibility (EMC). A device's EMC must ensure that no field-conducted or line-conducted influences may disturb the device.

As can be seen in Figure 2.1, electrical devices may be affected by fields which have an effect on the PROFIBUS/PROFINET lines, power supply lines, signal/control lines or the functional earthing of the device.




Figure 2.1: EMC interfaces of a device according to [RUD2011]

Besides the line-conducted disturbances shown in Figure 2.1, electric, magnetic and/or electromagnetic fields may additionally affect a device. However, these are not further considered here.

The conductive housings of automation system components are usually earthed due to reasons of electrical safety. Therefore, an equipotential bonding system in a plant is usually earthed as well. For this reason, this document does not differentiate between the connection to an earthing system and the connection to a potential equalization / equipotential bonding system. For technical reasons in many cases, the connection to an equipotential bonding system without earthing might be sufficient to fulfill the EMC requirements. This document will recommend in section 4.1.3 the use of a common bonding network (CBN) that serves the purpose of equipotential bonding, functional earthing and protective earthing. The expression CBN will be used in this document.

2.1 Couplings

A source of disturbance is only capable of disturbing another device if there are coupling lines. The coupling lines connect the source to the susceptible device (see Figure 2.2). In this context, the term “susceptible device” refers to electrical equipment such as PROFIBUS lines or a PROFIBUS device that may be affected by electromagnetic interference (EMI).




Figure 2.2: Coupling lines

The coupling lines shown in Figure 2.2: Coupling lines can be assigned to three different groups:

1. Line-conducted disturbances are caused by conductive connections between devices.
2. Nearby disturbances are produced by magnetic or electric fields causing inductive or capacitive coupling.
3. Emission lets disturbances in the form of electromagnetic waves propagate over long distances and couple into other devices (susceptible devices). This form of coupling is outside the scope of this document.

2.1.1 Conductive coupling

Conductive coupling requires partial currents from two circuits to flow through a common electrically conductive connection. This connection is also called coupling impedance. The common current flow of the two current circuits causes a voltage drop across the coupling impedance. This voltage drop produces a potential shift at both consumers (loads). Due to this potential shift, the voltage of the consumers/loads may fall below or exceed their rated voltage. [SCH2008]

Since the equipotential bonding system connects several circuits, it acts as a coupling impedance. If one circuit causes potential differences in the equipotential bonding system, these can affect another circuit via galvanic coupling. The drawings below illustrate the causes of potential differences in equipotential bonding systems.

Figure 2.3 shows a single current circuit in which the negative pole of the voltage source (U_1) has a connection to the common bonding system (CBN). Additionally, the line impedances (Z_L) and a consumer or load impedance (Z_C) are shown. The current I_1 flows from the voltage source across a line impedance to the consumer or load and returns via the second line impedance to the voltage source. No current flows through connector to the CBN, which only has to fulfill a safety function. As a result, conductive coupling into non-system current circuits is impossible.




Figure 2.3: Conductive coupling in equipotential bonding system 1

In Figure 2.4, you can see another connector to the CBN at consumer/load Z_C . Due to this second connection, a parallel current circuit is formed (see Figure 2.5) through the equipotential bonding system. The parallel current circuit is represented in the illustration by series-connected equipotential bonding system impedances (Z_E).




Figure 2.4: Conductive coupling in equipotential bonding system 2




Figure 2.5: Conductive coupling in equipotential bonding system 3

In Figure 2.6, a measuring instrument is connected to the equipotential bonding system. The measuring instrument indicates a potential difference between two points of the equipotential bonding system emerging due to the current flow through the equipotential bonding system.




Figure 2.6: Conductive coupling in equipotential bonding system 4

If current circuits are connected to the common bonding system (CBN) several times, be it intentionally or unintentionally, a part of the current may flow through the equipotential bonding system. As a result, potential differences occur in the equipotential bonding system, despite its low inductance. These potential differences affect, amongst other things, shielded cables that have multiple connections to the equipotential bonding system. As cable shields are connected to the housing of the device, and thus with the common bonding network (CBN) each cable end, currents from the equipotential bonding system may flow through the cable shield of a data line and hence couple disturbances into it.

2.1.2 Capacitive coupling

Capacitive coupling emerges between two conductors that have at least a conductive connection and a potential difference. Figure 2.7 shows two voltage sources (U_1 , U_2) with different voltages or shifted phases. Moreover, they are connected to the same equipotential bonding system. This connection and the different voltages produce an electric field between the cables. In the equivalent circuit diagram, the electric field is represented by a stray capacitance ($C_{1/2}$) [SCH2008].




Figure 2.7: Capacitive coupling

The potential difference between two signal cables that have the same reference to the common bonding network (CBN) is a simple example of capacitive coupling. Due to the potential difference between the two cables, an electric field emerges which may cause mutual interference.

2.1.3 Inductive coupling

Inductive coupling results from magnetic fields between two current circuits (① and ②). The alternating current (I_2) generates a magnetic field, which causes a magnetic flux. The magnetic flux crosses the mesh of the current circuit ① and induces a voltage in it. The induced voltage generates a current in current circuit ① which overlays the wanted signal and may impair the function of the current circuit [SCH2008].




Figure 2.8: Inductive coupling

Inductive coupling is a phenomenon that frequently occurs in practice because it only requires current circuits in which the current changes over the time, such as alternating currents or transient currents in switching actions (on or off) that are located in the vicinity of other current circuits. No conductive connection between the two current circuits is needed. Physical proximity suffices to produce a significant common coupling inductance M_{12} .

2.1.4 Radiated coupling

In industrial cables of usually up to 100 m of length, radiated coupling between high-energy disturbers and signal current circuits only occurs at high frequencies (approx. 30 MHz and higher). This type of coupling is caused by the electromagnetic field [SCH2008]. PROFIBUS and PROFINET cables are relatively well protected against radiated coupling by their high signal level, twisted wires and shielding. Usually, radiated coupling impairs the electronics of the connected devices, for example due to insufficiently shielded device housings or electronics with insufficient EMI shielding. As the design of PROFIBUS/PROFINET devices are beyond the scope of this document and only their cabling is covered here, radiated coupling is not considered any further.

2.2 Electrostatic discharge

Electrostatic charges emerge from major potential differences caused by friction or separation of different materials. Friction of different materials leads to the transfer of electrons (charge separation) between the two materials. Due to the electron transfer, one material collects a positive charge and one material a negative charge. Typical examples of electrostatic charges emerging in an industrial environment are charges produced by plastic containers on a conveyor. Filling bulk material or liquids from one vessel into another is also likely to produce electrostatic charges. The electrostatic charges are discharged as soon as there is a conductive connection between two materials with a sufficiently high potential difference or a spark is produced because the dielectric strength of the air gap is exceeded. The resulting high current flow may disturb sensors and the related data communication [KLE2016].

2.3 Typical sources of disturbance in automation systems

In industrial environments, there are many potential sources of disturbance that are likely to jeopardize the reliable and safe operation of automation systems. Most of the disturbances are caused by the types of coupling described in section 2.1. This is why disturbing equipment often features high performance and higher frequencies or short switching times. Typical potential sources of disturbance are, for example, frequency converters, welding systems, solenoid valves and switching operations. Table 2.1 shows the frequency spectrum of these potential sources of disturbance.

Table 2.1: Frequency spectrum of potential sources of disturbance from [SCH2008]

Type of equipment	Frequency spectrum
Motor	10 Hz to 50 MHz
Frequency converter	1 Hz to 10 MHz
Switching operations	1 kHz to 200 MHz
Rectifier systems	50 Hz to 5 MHz
Power electronics	100 Hz to 100 MHz

Various types of shielding measures and the functional bonding of equipment are used to protect automation systems against typical frequency-dependent sources of disturbance. The following section details the fundamentals of functional bonding and shielding.

3 Fundamentals of equipotential bonding and shielding

This section deals with protective measures against functional disturbances used in automation systems. The first subsection focuses on cable shielding and the second subsection considers equipotential bonding.

3.1 Cable shielding

Cable shields use two different principles to suppress the individual types of disturbance. These principles are called “active shielding” and “passive shielding”. They are explained in more detail in the following two subsections. Besides these two shielding measures, there are other protective measures such as the twisting of data wires in order to ensure undisturbed data communication via PROFINET and PROFIBUS cables.

3.1.1 Passive shielding

A shielding effect solely achieved by using shielding material of sufficient thickness is referred to as “passive” shielding. The minimum material thickness required for the shielding effect depends on two factors: firstly, the frequency of the disturbance and, secondly, the magnetic permeability of the material in the presence of magnetic fields. If the shield has a material thickness greater than the minimum required material thickness, eddy currents can occur inside the shield. The eddy currents generate a field that is oriented oppositely to the disturbing field. This nearly eliminates the disturbing effect. However, this shielding effect is normally not provided by cable shields, as their material thickness is insufficient and instead is usually achieved by metal-type cable ducts with separators and covers or steel tubes.

3.1.2 Active shielding

Due to the low material thickness of cable shields, the active shielding effect is used. However, for active shielding to work, it is necessary to connect the cable shield to the common bonding network (CBN) at several points in order to establish a current circuit [WOL2008].

Figure 3.1 shows the schematic structure of capacitive coupling between two circuits. The added metallic cable shielding (shown in gray color in Figure 3.2) splits the capacitance $C_{1/2}$ of Figure 3.1 into two capacitances C_1 and C_2 , as shown in Figure 3.2.




Figure 3.1: Repetition of capacitive coupling




Figure 3.2: Active shielding with one-sided connection to the common bonding network (CBN)

When the cable shield is connected to the Common Bonding Network (CBN), it has the potential 0 V and provides a low impedance return path to the source U_2 . Coupled displacement currents ($I_{displacement}$) from circuit ② can thus flow off via the shield and have no effect on circuit ①. This effect is called "active shielding against electric fields".

If the cable shield has two or more connections to the common bonding network (CBN), there is an additional shielding effect against magnetic fields called “active shielding”. When exposed to magnetic fields, a voltage is induced due to multiple connections of the cable shield to the common bonding network (CBN), and the induced voltage allows a current (I_{shield}) to flow in the cable shield (Ⓢ), as shown in Figure 3.3. This current flows back via the equipotential bonding.




Figure 3.3: Induction in the cable shield

The induced current flow produces a counter-induction with a 180° phase shift to the initial induction of the magnetic field. This cancels the magnetic flux through the area enclosed by the current flow I_{shield} and reduces the voltage induced in the wire bundle.

For this reason, cable shields should be connected to the common bonding network (CBN) at least at both ends in order to achieve a sufficient shielding effect against magnetic fields and alternating electromagnetic fields.

3.2 Equipotential bonding

Earthing points can be found everywhere in a plant or on plant equipment. A distinction is made between protective earthing (PE) and functional equipotential bonding. Protective earthing is intended to ensure the safety of humans and to prevent hazardous touch voltages on housings and other conductive parts. Functional equipotential bonding, in contrast, serves the equipotential bonding of devices that is not safety relevant.

3.2.1 Protective earth conductor (PE)

The protective earth conductor ensures protection of electrical active devices with the protective measure “protective earthing” in the event of a fault. It facilitates the protection of persons against electrical shock by indirect contact.

Indirect contact is caused by an electrically conductive, usually metallic, object of electrical active devices, which may build up an electrical voltage to earth in the event of a fault. Such a fault scenario could be a 230 V cable, which has accidentally come loose and come in to contact with a metal part of the device. Therefore, every electrical device with an operating voltage above 50 VDC or 120 VAC must have a PE-terminal for the protective earth conductor.


3.2.2 Protective equipotential bonding

A different setting applies for electrically passive, but touchable, conductive parts of the plant, e.g. a handrail, a protective fence or a roller conveyor. Here no PE terminal is present. However, it is recommended to connect those parts of the plant to the protective equipotential bonding system.

If a handrail is connected to the protective equipotential bonding system, then - in the case of an error (phase connected to the handrail due to failure of basic and additional insulation) - a fault current can trigger a protective device like a fuse or an RCD and switch off the circuit.

As the handrail is connected to the protective equipotential bonding conductor, a fault current of sufficient intensity is produced and triggers a safety device (fuse, fault current circuit breaker) to disconnect the current circuit from mains. If, however, the handrail were not connected to the protective equipotential bonding conductor, a voltage of 230 V would be present between the handrail and earth, presenting a danger to the life of humans and (farm) animals that might come into contact with it. It is therefore recommended to connect all passive, electrically conductive objects such as pipes, protective fences, ladders, handrails, metal cable ducts or other structural components to the protective equipotential bonding in order to prevent impermissible touch voltages.

In this document, the connection of electrical equipment to a protective conductor or protective equipotential bonding is marked by the following symbol:



3.2.3 Functional equipotential bonding (FE)

“The purpose of functional equipotential bonding is the reduction of:

- the effects of an insulation fault that may affect operation of a machine;*
- the effects of electrical disturbances on sensitive electrical equipment that may affect operation of a machine.” [DIN-EN 60204-1]*

This means that functional equipotential bonding does not serve the safety of humans and (farm) animals, but the functional reliability of a plant. Among the objects that are usually connected to the functional equipotential bonding are, for example, motor shields, data cable shields and functional bonding conductors of sensitive component parts.

In this document, the connection of electrical equipment to a functional equipotential bonding is marked by the following symbol:



4 Recommendations for the design of PROFIBUS and PROFINET networks with little disturbance

These recommendations provide instructions on how to design systems with only little disturbance. The individual recommendations deal with the following:

- Combination of protective and functional equipotential bonding systems to form a common network
- Implementation of 230/400 V power supply differentiation between the individual types of earthing for network systems (TN-S, TN-C, TN-C-S, TT and IT)
- Minimum distances between power cables and PROFIBUS/PROFINET cables
- Setup of the equipotential bonding system
- Connection of PROFIBUS/PROFINET cable shields
- Peculiarities of motor cables
- Connection of the negative pole in a 24 V power supply circuit to the common bonding network (CBN)

The following subsections provide general explanations and problem descriptions for all seven topics on the basis of standards and specialist literature. Additionally, a recommendation for the functional bonding and shielding of PROFIBUS/PROFINET networks is derived from the standards. This chapter gives recommendations for the manufacturing industry, while chapter 5 relates the given recommendations to the process industry. In chapter 5 the area with explosive atmosphere in particular is considered, since additional guidelines for the equipotential bonding and shielding of cables apply in this area. For bus lines that either leave the building envelope or are laid outdoors the applicable lightning protection directives must also be observed in addition to this document. It is recommended to preferably use fiber optic cables as bus lines that leave buildings or are supplied from different main distributors.

Figure 4.1 shows a manufacturing plant. In this plant, robots ⑥ transport various components between conveyors ⑦ and processing tables ⑧.




Figure 4.1: Plant example from the manufacturing industry

Like in the plant example from the process industry described above, the manufacturing plant in this example is supplied via the low voltage main distributor ① (LVMD); the cabinet accommodates the programmable logical controller ③ and several frequency converters ② for operating the motors ⑤. Some decentralized remote I/O units ④ are located in the field of the plant. In this plant example, you can see an exemplary presentation of the following problems: Control of drives/actuators, wide-spread plants with conveyors and connection of robots.

4.1 Combination of protective and functional equipotential bonding systems

In the manufacturing industry and in the process industry both separate and common protective and functional equipotential bonding systems are used. Separating the two systems is reasonable under the assumption that in this case no currents flowing in the protective equipotential bonding system can couple into the functional equipotential bonding system, causing disturbances. Protective equipotential bonding serves the safety of humans and (farm) animals. Functional equipotential bonding serves to ensure full plant functionality, for example by eliminating disturbances caused by electromagnetic fields. Both equipotential bonding systems are laid out in a star or tree topology distributed over the entire plant area, and they are interconnected at a just one point. Usually, the central protective earth connector (Main Earth Terminal) of the plant is used as the connection point for the protective and the functional equipotential bonding systems.

4.1.1 Problem description

Nowadays, having completely separated functional equipotential bonding and protective equipotential bonding systems in a plant is no longer practical as there are always several points in a plant where unwanted connections are likely to occur.

For example, the usage of PROFIBUS and PROFINET may result in a connection between the functional and the protective equipotential bonding system. In order to ensure full functionality of PROFIBUS/PROFINET lines, you have to connect each line end to the functional equipotential bonding system (see section 3.1.2).

To achieve this, the cable shield has to be connected to a large contact surface on a PROFIBUS/PROFINET connector housing, a separate equipotential bonding bar or a suitable shield connector at the device. This measure already satisfies the requirement to connect the functional and the protective equipotential bonding systems to each other.

4.1.2 Solutions from standards and specialist literature

No standard requires a strict separation of the functional and protective equipotential bonding systems. In the standard [DIN-EN 60204-1] you will find an explanation on how to achieve functional equipotential bonding by means of a connection to the protective equipotential bonding system. If, however, the protective equipotential bonding system is heavily loaded by currents, providing a separate functional equipotential bonding system may become necessary.


Hence, when using a common equipotential bonding system it must be ensured that the currents flowing through it are as low as possible.

Additionally, the standard [IEC 60364-5-54] requires that common protective and functional equipotential bonding conductors always have to meet the requirements on protective conductors. With this, the minimum cross-sectional areas, line impedances, minimum ampacity and protection against self-loosening of equipotential bonding conductors are clearly defined.

4.1.3 Recommendations for PROFIBUS and PROFINET

As already stated, a strict separation of functional and protective equipotential bonding systems is not feasible in practice, as unintended connections between the two bonding systems frequently occur. Moreover, attempts to separate the two systems can incur high costs. Common equipotential bonding is therefore recommended. A common equipotential bonding system of this kind is referred to as Common Bonding Network (CBN). It combines both the protective functions required for triggering circuit breakers in case of a fault and the functional equipotential bonding functions for avoiding electromagnetic interference.

In this document, the following symbol is used for marking a CBN connection:



Please note that this symbol is just used for the purpose of this document. In the relevant standards on this subject you can find different symbols for this.

From this section of the document, the first recommendation M1 is derived:

M1	Provide combined protection and functional equipotential bonding (CBN)
----	--

4.2 Implementation of 230/400V mains supply

This section deals with the reduction of disturbances and loads of the equipotential bonding system by using the appropriate mains supply network systems. The standard [DIN-VDE 0100-100] specifies several mains supply network systems. They are called TN-S, TN-C, TT and IT systems and are shown in Figure 4.2.




Figure 4.2: Network systems

In the TN-S, TN-C and TT systems shown in Figure 4.2, the neutral point of the feeding transformer is connected to protective earth. The neutral point in an IT system is not earthed and a neutral conductor may or may not exist in an IT system.

In TN and TT systems, the star point of the transformer is earthed. In TN-S networks the protective earthing of the device takes place via the protective earth conductor, that is grounded at the star point of the transformer. In TN-C networks the protective earthing of the device is performed via the combined Protective / Neutral conductor (PEN). The protective conductor and the neutral conductor in a TN-C system are parts of a common

conductor line. In a TN-S system, on the contrary, the protective conductor and the neutral conductor are laid separately.

In a TT system, the neutral point of the transformer is earthed. There is no protective conductor connection between the neutral point of the transformer and the connected devices. These are earthed locally. [SCH2008]




Figure 4.3: TN-C-S system as network system

A TN-C system and a TN-S system can be combined to form a TN-C-S system. Figure 4.3 shows a TN-C-S system. In this TN-C-S system, Device 1 is connected to the TN-C system, whereas Device 2 is connected to the TN-S system. The connection of the systems between the two devices is achieved by separating the previously used PEN conductor into a protective conductor and a neutral conductor. It is important not to re-combine the separated N conductor and PE conductor to form a common PEN conductor again.

The type of mains supply is defined when deploying the energy supply system. It determines whether using a TT system, TN system or IT system is possible or not. Normally, power is supplied via a TN-C system; therefore, the recommendation at the end of this section is based on this system type.

4.2.1 Problem descriptions

4.2.1.1 Mains supply network as TN-C system

In Figure 4.4, a cabinet powered via a low voltage main distributor (LVMD) and a TN-C system is shown. In addition to the three active conductor lines (L1, L2, L3), the LVMD comprises the PEN conductor. This is a typical conductor in a TN-C system and it combines the protective conductor and the neutral conductor. In order to simplify the illustration, no fuses, terminals, meters etc. are shown. Nevertheless, they will have to be considered later on in the planning phase of the system. Additionally, an exemplary representation of the central earthing point can be seen in the LVMD. The central earthing point connects the foundation earth electrode to the PEN conductor at one point.

The low voltage main distributor is powered via a transformer. Figure 4.4 only shows the secondary circuit of the transformer.




Figure 4.4: TN-C system

In the following step, the current flow is considered. For this reason, in Figure 4.5 a single-phase motor is connected into the circuit between L1 and PEN as a load.




Figure 4.5: TN-C system with load

Figure 4.6 illustrates the current flow generated by the motor that has been connected into the circuit. The current flows from the transformer via L1 to the motor. It returns from the motor via its neutral conductor to the distribution panel in the cabinet and from there via the PEN conductor to the transformer.




Figure 4.6: TN-C system with load and current flow

Problems will occur in the TN-C system as soon as the PEN conductor is connected intendedly or unintendedly to the equipotential bonding system. Such an additional connection may occur at the motor shaft or the motor fastening point to a metal support, owing to the construction. In Figure 4.7, the connection of the motor to the equipotential bonding system is shown under ① as an example.




Figure 4.7: TN-C system with several connections to the equipotential bonding system

Figure 4.8 shows another possible current flow than Figure 4.6, considering the potential current flows at the motor and the existing connection to the equipotential bonding system. In this case, the current flows from the motor via the N conductor back to the PEN conductor of the cabinet. The major part of the current will flow via the PEN conductor to the LVMD and to the transformer. A partial current, however, will also flow through the PE conductors to the motor housing and return from there through the equipotential bonding system to the LVMD earthing point and to the transformer.




Figure 4.8: TN-C system with multiple earthing, load and current flow

A potential difference between the two earthing points emerges due to the current in the equipotential bonding system and to the voltage drop caused by the current flow. This potential difference may be bridged by the cable shields of the motor and data lines, as the cable shields are connected to the equipotential bonding system at several points. However, the cable shields are not designed for carrying operating currents and may be damaged due to excessive current load.

4.2.1.2 Mains supply network as TN-C-S system

The new TN-S system has been developed from the TN-C system, which is rather outdated seen from the vantage point of the present. In this case, the neutral conductor and the protective conductor are implemented separately. It is, however, also possible to combine both systems. The combination, called TN-C-S system, is shown in Figure 4.9. The system in the LVMD is still a classical TN-C system with a PEN conductor. In the cabinet, the protective conductor and the neutral conductor are separated from each other, making the system a TN-S system. The only connection between these two conductors is a PEN bridge.




Figure 4.9: TN-C-S system

The current flow through the motor connected into the circuit in Figure 4.9 as an exemplary load is shown in Figure 4.10 in red. The current flows from the transformer via the conductor line L1 through the LVMD and the cabinet to the motor. From the motor, it flows via the neutral conductor to the cabinet and returns from there via the PEN conductor in the LVMD to the transformer.




Figure 4.10: Current flow in a TN-C-S system

As the motor may have several intended or unintended conductive connections to the equipotential bonding system, the current flow shown in Figure 4.11 is also possible. In this example, the current does not only return from the cabinet to the LVMD via the PEN conductor, but also - as a partial current - via the protective conductor of the motor and the equipotential bonding system.




Figure 4.11: Current flow in a TN-C-S system with multiple earthing

As this current flow may not only cause damage to the equipotential bonding system, but could also affect other components such as motor bearings or gears, it is recommended to intentionally implement a second connection between the equipotential bonding system and the protective conductor of the TN-S system in the cabinet. Such a connection is shown in Figure 4.12. Earthing considerably reduces the current flow through the protective conductor to the motor.




Figure 4.12: Current flow in a TN-C-S system with targeted multiple earthing

The taken measure, i.e. the connection of the protective conductor to the equipotential bonding system when implementing the TN-S system in the cabinet protects the connected loads against operating currents through the protective conductor. However, the current flow through the equipotential bonding system is not prevented. The residual current flow is still capable of damaging the cable shields of data lines.

4.2.1.3 Mains supply network as TN-S system

Seen from the vantage point of the present, it is better to have pure TN-S systems or to separate the individual components of the plant's PEN conductor early. The separation is made in the LVMD, as shown in Figure 4.13.




Figure 4.13: TN-S system

In Figure 4.13, the central earthing point of the equipotential bonding system in the LVMD is only connected to the protective conductor. Additionally, a PEN bridge is provided at the central earthing point (CEP) in the LVMD.

For the purpose of demonstrating the current flow in the TN-S system in Figure 4.14, a motor is connected into the circuit next to the cabinet as an additional load. Both the cabinet and the motor have other connections to the equipotential bonding system.




Figure 4.14: TN-S system with load

When considering the (red) current flow in Figure 4.15, it is noticeable that no current flows through the equipotential bonding system, although the housings of the equipment units feature multiple earthing. The current flows from the transformer across conductor line L1 to the load and returns to the transformer through the neutral conductor. This is the TN-S system's major advantage over the TN-C system.




Figure 4.15: TN-S system with load and current flow

Figure 4.16 shows a fault that is often encountered with TN-S system in practice. Besides the necessary PEN bridge in the LVMD, another PEN bridge has been erroneously installed in the cabinet.




Figure 4.16: TN-S system with two PEN bridges

According to [DIN-EN 60204-1], implementing a second PEN bridge in the cabinet is forbidden. The reason for this is clearly seen in Figure 4.17.




Figure 4.17: : TN-S system with two PEN bridges, load and current flow

The current flow shown in Figure 4.17 in red first flows from the transformer through L1 to the load, as already discussed above. At this point, however, the current reaches the neutral conductor of the cabinet and flows to the incorrectly installed PEN bridge. At the PEN bridge, the total current is divided into several partial currents. As a result, there is a parallel back current via the equipotential bonding system, the protective conductor and the neutral conductor to the transformer. The current flow in the equipotential bonding system causes a potential difference between the two earthing points. This potential difference creates difficulties, as it may cause, among other things, current flows in the cables shields (see section 2.1.1).

4.2.2 Descriptions in the relevant standards and specialist literature

According to [DIN-EN 50310] and [IEC 60364-4-44], TN-C systems are not suitable for installations in buildings with IT equipment, due to non-compliance with EMC requirements. This is mainly due to the PEN conductor. For operational reasons, the PEN conductor leads neutral conductor currents which may cause potential differences in the equipotential bonding system due to multiple connections with it. Moreover, the currents in the equipotential bonding system also flow through the cable shields of motor and data lines which have to be earthed at each end in order to ensure their active shielding effect. The currents flowing in the cable shields cause disturbances in the plant [SCH2008], because they affect the communication between the connected devices. These disturbances may even result in plant down times.

For this reason, the designers and constructors of new buildings/plants with IT equipment are requested in [DIN-EN 50310] and [IEC 60364-4-44] to use TN-S systems only.

4.2.3 Recommendations for PROFIBUS and PROFINET

Due to the advancing digitalization in the process and manufacturing industries, it must be assumed that all buildings in manufacturing plants (will) have IT equipment. To ensure electromagnetic compatibility, it is recommended to use only TN-S systems, TN-C-S-systems, where the PE and the N conductor are preferably already separated in the LVMD or TT-systems. If a TN-C system exists already for power supply from the energy supply company, it should be converted into a TN-S system in the low voltage main distributor system as early as possible, for EMC reasons. To achieve this, a PEN bridge should be installed close to the central earthing point. In a TN-S system, there may be several parallel connections, for example from the cabinet to the equipotential bonding system, without any operating currents flowing through the equipotential bonding system. Additionally, current monitoring at the PEN bridge is possible, as shown in Figure 4.18. For current monitoring, the direct and alternating currents across the PEN bridge are measured and evaluated; the current monitoring equipment should be installed and handled by qualified personnel. Current monitoring allows for early recognition of impermissible currents. Early recognition facilitates the recognition of currents flowing in the equipotential bonding system as well as impermissible multiple connections between the neutral conductor and the protective conductor.




Figure 4.18: Ideal TN-S system

When modernizing the power supply equipment in existing buildings, it is often necessary to change the TN-C systems used so far into TN-S systems. For this purpose, a new protective conductor is installed and the equipment is connected to it. The previously used PEN conductor can only be re-used as a neutral conductor, provided that it has an appropriate cross sectional area (CSA) and is in a re-usable state. It must be ensured that there is only one connection between the protective conductor and the previously used PEN conductor in the LVMD. Any additional connection must be avoided in the TN-S system [WOL2015].

From this section of the document, the second recommendation M2 is derived:

M2	Preferably use a 230/400 V power supply using a TN-S system.
----	--

4.3 Equipotential bonding system

A plant example from the manufacturing industry is used here for explanation. Of course, the principles of equipotential bonding are also applicable to plants in the process industry.

At present, equipotential bonding systems are usually implemented in a star or tree topology. Figure 4.19 shows an equipotential bonding system with star topology. The loads/devices in the plant are not only connected to the equipotential bonding system, but also to additional protective conductors in the connection cables of the devices. This is due to the fact that every power cable has a protective conductor which additionally provides for protective earthing of the equipment.




Figure 4.19: Star-type equipotential bonding

It is, however, more cost-saving to implement the equipotential bonding system in a tree topology rather than using a pure star topology (Figure 4.20). In a tree topology, several neutral points are combined in a central neutral point.




Figure 4.20: Tree-type equipotential bonding

4.3.1 Problem description

The problems that may arise due to equipotential bonding are almost the same for star topologies and for tree topologies. Therefore, only star topology equipotential bonding systems will be considered in the following sections.

In Figure 4.21, you can see a star topology equipotential bonding system in green and yellow and a PROFIBUS line in violet. The PROFIBUS line in the example could also be replaced with a PROFINET line, as both network types allow for a line-type system structure.




Figure 4.21: Equipotential bonding system in star topology with PROFIBUS lines

PROFIBUS and PROFINET lines are shielded two-wire, four-wire or – in the future – eight-wire lines. Usually the cable shields are connected to the housings of the connectors and through this with the housings of the devices. It is specified in the planning guidelines that the cable shields have to be connected to the Common Bonding Network (CBN) at both ends. This is important for the protective function of the cable shield in terms of EMC, because cable shields that are not connected to the common bonding network (CBN) or are only connected at one end do not provide for active shielding against magnetic fields (see section 3.1.2).

Figure 4.22 shows details of the connection between the cable shield and the equipotential bonding system. The green and yellow lines of the equipotential bonding system with saturated colors have direct connections to the cable shields of the PROFIBUS line. The pale-colored lines of the equipotential bonding system have no direct connection to the cable shield and are not relevant for further considerations. As a result, these pale-colored lines are hidden in the following illustrations.




Figure 4.22: Equipotential bonding system in star topology with PROFIBUS lines 2




Figure 4.23: Equipotential bonding system in star topology with PROFIBUS lines 3

The connections of the equipotential bonding system's neutral points to the cable shields of the PROFIBUS line connected to these points form the meshes shown in red in Figure 4.24. If the mesh conductors are exposed to magnetic fields, voltages may be inductively coupled into them. Due to the in-coupled voltage, a current flows in the mesh conductors and, hence, through the cable shield of the PROFIBUS line.

Chapter 3.1.2 described active shielding, which requires a shielding current to cancel out incoming magnetic fields. In this case, the current flow on the shield is required to achieve the shielding effect. However, if the shielding current is not caused by a magnetic field incident on the PROFIBUS cable, but instead flows, for example, as a compensating current of a galvanic coupling in the equipotential bonding system, it generates interference instead of reducing it. This interference current via the shield should be prevented.

Additionally, an equipotential bonding system in star topology has long transmission routes. The long transmission routes cause high impedances of the equipotential bonding lines. If a current is coupled into the equipotential bonding lines, the resulting current flows through the shield of the PROFIBUS line (see section 2.1.1). The resulting current flowing through the cable shield couples disturbances into the data wires of the PROFIBUS line.




Figure 4.24: Meshes in an equipotential bonding system with star topology

In the past, it was recommended to use equipotential bonding lines with large cross-sectional area (CSA) and lay them in parallel with the bus line and very close to it and typically connect them only to the devices in order to avoid current flows through the PROFIBUS line shields. These lines are shown in Figure 4.25.




Figure 4.25: PROFIBUS lines and equipotential bonding lines

The main idea behind the setup shown in Figure 4.25 is to make disturbance currents flow through the low-resistance equipotential bonding line rather than through the cable shield of the PROFIBUS line, while maintaining the effect of active shielding.

As the disturbance currents in plants usually have high frequencies (see Table 2.1), it is the impedance and not the ohmic resistance that is important for determining the current distribution in the equipotential bonding system. As the impedance of a cable shield is considerably lower than that of a solid copper conductor the major part of the current potentially occurring in the mesh will flow through the cable shield and not through the equipotential bonding conductor laid in parallel and intended to work as a relief line.

As can be seen in Figure 4.26, the additional equipotential bonding lines do not present any improvement regarding the mesh size. The meshes are still big and, thus, sensitive to inductive coupling.




Figure 4.26: Meshes with PROFIBUS lines and equipotential bonding lines

4.3.2 Solutions from standards and technical literature

The standards [DIN-EN 50310] and [IEC 60364-4-44] specify the earthing and equipotential bonding measures for buildings with IT equipment. The explanations in the following section have been derived from these standards. In the [DIN-EN 50310] standard, four different types of equipotential bonding systems are distinguished, which are shown in Figure 4.27.




Figure 4.27: Equipotential bonding systems referring to [DIN-EN 50310]

The equipotential bonding system type A has a star topology. Due to the usually long transmission paths this star-topology system features high impedance between two devices. The high impedances cause poor discharge of electromagnetic disturbances coupled into the system. Seen under the aspects of EMC, type A systems are the least suitable equipotential bonding systems for buildings with IT equipment, due to their high impedance.

The equipotential bonding system type B has a ring topology. Although the ring topology reduces the length of the protective conductors between two devices, the lines may nevertheless feature high impedances, which, again, may affect or even prevent proper discharge of electromagnetic disturbances/coupling.

The equipotential bonding system of type C has a locally meshed equipotential bonding line. In the plant area, all metal parts such as cabinets, frames, supports and cable systems are locally meshed. By connecting all metal parts, a meshed equipotential bonding system is formed, which features a low impedance due to its big number of short and

parallel transmission routes. A network with this kind of meshing of all conductive objects is called a Bonding Network (BN).

The equipotential bonding system of type D has meshed equipotential bonding lines distributed over the entire building. Therefore, a common system should be laid over several levels of the building (see Figure 4.28).




Figure 4.28: Meshed equipotential bonding system

The [DIN-EN 50310] recommends to use only meshed equipotential bonding system of type D for newly built IT systems. A meshed equipotential bonding system of this kind is also called a MESH-BN¹ if it is based on a common bonding network (CBN).

The goal of using a meshed equipotential bonding system is to reduce the line impedance between two devices. For this purpose, as many parallel and electrically conductive connections as possible are needed between the devices of the plant. As this would induce a tremendous cabling effort if only cables were used, the meshing is in parts realized by using the metal parts of the plant such as pipes, frames, cabinets and cable ducts. According to the [DIN-EN 62305-4] standard, it is also possible to include the foundation earth electrode and the steel arming on the building floors into the equipotential bonding system. In this case, however, the steel arming of the foundation earth electrode must be either welded or permanently connected by other measures in order to ensure electrical conductivity. [DIN 18014]

¹ A MESH-BN is a meshed equipotential bonding system in which all supports, cabinets, robots, pipes and frames of the plant equipment are connected to each other and, at many points, to the equipotential bonding system (CBN).

For new or modernized plants, a meshed equipotential bonding system can be easily implemented. For plants with already existing equipotential bonding systems in star or ring topology there are suggestions for improvement by additional connections. The suggested improvements are shown in Figure 4.29. On the left-hand side of the image you can see the initial equipotential bonding system, and on the right-hand side the improved system. The improvement consists in adding equipotential bonding conductors between the devices, which are represented by thick lines in the drawing.




Figure 4.29: Improved equipotential bonding systems referring to [DIN-EN 50310]

4.3.3 Recommendations for PROFIBUS and PROFINET

The [DIN-EN 50310] standard is applicable to automation systems with PROFIBUS/PROFINET devices. When constructing or reconstructing such systems, a meshed equipotential bonding system that comprises the entire copper-based PROFIBUS/PROFINET network should be implemented. A meshed equipotential bonding system for the manufacturing plant example discussed earlier in this document could look like the example shown in Figure 4.30. In plants with considerable field loads such as induction furnaces or industrial microwave ovens, additional measures like double shielding or cable laying in metal pipes might be necessary.




Figure 4.30: Meshed equipotential bonding

In the following section, meshed equipotential bonding in accordance with the [DIN-EN 50310] will be explained step by step. Lines with ring topology forming big meshes around dedicated plant sections are the basis of this type of equipotential bonding. The meshes are shown in Figure 4.31.




Figure 4.31: Ring lines in meshed equipotential bonding system

In order to ensure a low impedance, even at high frequencies, the lines shown in Figure 4.31 should be tin-plated or multi-wire copper lines. Lines of this type are also recommended in [DIN-EN 61918].

In Figure 4.32 you can see additional lines between the ring lines and the devices of the plant example. These stubs should be as short as possible. Additionally, the devices should be connected to the ring line at several points in order to form many small meshes. And the devices should be conductively interconnected to form a bonding network. All connections must comply with the requirements of protective and functional equipotential bonding, i.e. they must feature a low impedance and a sufficient ampacity. And the appropriate measures must be taken to avoid unwanted loosening of the equipotential bonding points during plant operation.



Figure 4.32: Stubs of the meshed equipotential bonding system

In order to keep the branching points of the stubs on the ring line as simple and cost-saving as possible, the connection blocks shown in Figure 4.33 and Figure 4.34 can be used.

The connection blocks (Figure 4.33) are connected to the cable tray and at the same time provide the connection of the cable trays with the CBN through the connected ring line.



Figure 4.33: Connection blocks (WPAK clamps)




Figure 4.34: Stubs from ring line to devices (Picture Weidmüller)

Figure 4.34 shows the fine-wire ring line of the equipotential bonding system in silver/gray color. It is screwed to the cable tray through bronze-colored connection blocks. The connection block allows connecting stubs to the devices. The connection of the stubs is shown in Figure 4.34. The integration of the metal cable trays into the common bonding network (CBN) gives a good basis for a low impedance-bonding network. N. B: In any case, a conductor and connection blocks have to be used. The sole use of the cable tray as CBN is not allowed.

Figure 4.35 shows the next optimization opportunity offered by a meshed equipotential bonding system. On the ring line, there are additional earthing points, which are marked in red in the picture. These earthing points symbolize additional connections with the equipotential bonding system of the building. These additional connections further lower the impedance of the entire equipotential bonding system.




Figure 4.35: Meshed equipotential bonding via the foundation earth electrode

For the sake of electrical safety, the CBN must be connected to the foundation earth electrode at least at one point. By adding more connection points, the foundation earth electrode can become a part of the CBN and hence improve the local meshing of the equipotential bonding system. Moreover, an equipotential bonding system over several building levels is realized in this way, as the foundation earth electrode is integrated in the supports and columns of the building construction. These additional access points to the foundation earth electrode must be considered already in the early design phase of the building.

Figure 4.36 shows how the foundation earth electrode can be integrated: it is grouted into the concrete and can be connected to the equipotential bonding system through a screw if required. [DIN-EN 62305-4]




Figure 4.36: Earthing points [DEH2016]

The following two figures clearly show the big advantage resulting from meshed equipotential bonding. Figure 4.37 shows in red color a mesh formed by the cable shield of the plant's PROFIBUS line connected at each end. The meshes are considerably smaller than those used before in a star-topology equipotential bonding system (Figure 4.26). As a result, less inductive coupling is likely to occur in the meshes of the equipotential bonding system.




Figure 4.37: Mesh formed by a cable shield in a meshed equipotential bonding system

Additionally, many small meshes instead of few large ones are produced by meshing the equipotential bonding system. They are shown in the example in Figure 4.38. Due to the smaller meshes the equipotential bonding system has a lower impedance, which prevents potential differences.




Figure 4.38: Many small meshes in a meshed equipotential bonding system

Besides the lower impedance, smaller meshes provide another benefit with respect to electrostatic discharge. Non-metal conveyors, e.g. made of rubber or plastics, may cause electrostatic charges in a plant.




Figure 4.39: Example of electrostatic discharge

Upon electrostatic discharge the generated currents return to their place of origin. Therefore, plant sections where electrostatic discharge is likely to occur should be conductively interconnected. A finely meshed equipotential bonding system improves the impedance of such connections along the conveyance path.

The statements with respect to a fine granular meshed equipotential bonding system also apply to the interior of cabinets and the interconnection between cabinets. A good equipotential bonding system should be also established inside cabinets. A blank metal mounting plate (e.g. a tinned steel sheet) in combination with blank metal DIN-rails can achieve this, for example. The mounting plate shall be tied to the common bonding network (CBN) with low impedance. When using multiple cabinets, strung together, it is recommended to connect the mounting plates of the adjacent cabinets by ground straps.

From this section of the document, the recommendation M3 is derived:

M3

Design combined equipotential bonding system (Common Bonding Network CBN) as finely meshed as possible (MESH-BN).

4.4 Connection of PROFIBUS/PROFINET cable shields

The PROFIBUS or PROFINET cable shields are connected through the connector plug. Inside the connector, the cable shield is connected to the connector housing. The connector housing is connected to the equipotential bonding system, usually via the connector plug and the connected device.

4.4.1 Problem description with solutions from standards and technical literature

As the cable shield makes use of the active shielding principle, the shield should be connected to the equipotential bonding system at least at each end. Only then the currents generated by alternating magnetic fields can flow through the cable shield and generate an opposing field. Within the area enclosed by the shield current, this opposing field cancels out the magnetic flux between the cable and the equipotential bonding system. This lowers the voltage induced in the core bundle of the data cable and thus reduces the interference.

In order to allow the induced current flow to emerge freely, it is important that the connection between the cable shields and the connector housings have a low impedance. For this reason, connector housings that allow for low-impedance connections on a large contact area between the cable shield and the device should be used preferably [NE 98].

However, a low-impedance connection between the connector plug and the cable shield does not, on its own, produce a low impedance path for the currents. It will also be necessary to ensure that the connected devices (PROFIBUS or PROFINET) have a low-impedance connection between the connector shroud and the connection to the common bonding network (CBN).

Note: Grounding the shield does not serve the purpose of equipotential bonding of the system.

A low impedance connection of the cable shield, connector housing and the housing of the PROFINET-device is a requirement for a good EMC. In case a device does not yield a sufficient contact of the cable shield via the described path, an additional shield connection can be established close to the device. Figure 4.40 shows as an example of such a cable shield connection to the common bonding network (CBN) next to the device.




Figure 4.40: Connection of the cable shield to CBN close to a PROFINET device

If the environmental conditions allow for additional connections of the cable shield to the common bonding network (CBN), these are permitted according to [NE 98].




Figure 4.41: Multiple connection of the cable shield of a PROFIBUS line with the CBN

Figure 4.41 shows two PROFIBUS lines. The upper line is connected to the common bonding network (CBN) at its ends, only, whereas the lower line has two more connection points. Every supplementary connection of the cable shield of the lower PROFIBUS line shown in Figure 4.41 with the equipotential bonding system reduces the size of the mesh into which electromagnetic disturbances or fields could be connected. Of course, the impedance of the equipotential bonding system is of major importance. For this reason, a meshed equipotential bonding system should be set up as described in section 4.3. Figure 4.40 shows an example of such an additional cable shield connection.



Figure 4.42: Additional connection of the cable shield [NIE2017]

4.4.2 Recommendations for PROFIBUS and PROFINET

For PROFINET and PROFIBUS connections, special attention should be paid to the connector housing which should have a large contact surface for the cable shield. Additionally, the PROFIBUS and PROFINET devices should have a low-impedance connection to the CBN to be able to easily discharge disturbance currents. As already stipulated in the Installation Guidelines for Cabling and Assembly ([PRO2022] und [PRO2020]) from the PROFIBUS User Organization, the PROFINET and PROFIBUS lines can also be connected to the common bonding network (CBN) at bus nodes using respective clamps. This additional connection to the common bonding network (CBN) through clamps may bridge high impedances from the connector plugs that may occur.

From this section of the document, the recommendation M4 is derived:

M4

Provide a connection of the PROFIBUS/PROFINET cable shields through the housings of the connectors and through the housings of the devices and thus to the common bonding network (CBN) at each cable end with big contact surfaces (low impedance).

4.5 Motor lines

This recommendation intends to reduce electromagnetic interference in a plant. Many vendors of frequency converters recommend using shielded motor lines. Shielding the motor lines reduces the emission of electrical, magnetic and electromagnetic fields by the motor lines to an acceptable level. With this, it prevents disturbance coupling into lines laid in parallel with it.

4.5.1 Problem description

As shown in Figure 4.43, the cable shield is run around the active conductor lines (L1, L2, L3) and the protective earth conductor (PE) of the motor line. The shielding reduces the propagation of electromagnetic interference from inside the lines to other current circuits located near the motor line to an acceptable level. Coupling inside the line, however, is not suppressed by the cable shield. This means that disturbances in an internal conductor of the line may be coupled into other internal conductors through electric or magnetic fields.




Figure 4.43: Shielded motor line

4.5.1.1 Capacitive coupling in motor lines

Capacitive coupling occurs as soon as there is a potential difference between two parallel lines. The potential differences between the three conductor lines L1 to L3 are produced by the 120° phase shift between the individual line voltages. Additionally, the pulse width modulation of the frequency converter causes additional capacitive currents between the individual phases of the protective conductor and the cable shield. As both the shield and the protective conductor are usually voltage-free, additionally potential differences to the conductor lines L1 to L3 occur. As a result, there are various coupling capacitances inside a motor line which are shown in Figure 4.44.




Figure 4.44: Capacitive coupling in shielded motor lines

4.5.1.2 Inductive coupling in motor lines

The current flow in the conductor lines L1 to L3 generates several magnetic fields in the motor line. Therefore, magnetic field lines surround every conductor in Figure 4.45.




Figure 4.45: Magnetic field lines in a motor line

The magnetic field lines couple inductive disturbances into the other conductors of the motor line. Figure 4.46 illustrates this fact for a better understanding.




Figure 4.46: Inductive coupling between L1 and L2

Figure 4.46 shows the coupling inductance M_{12} between the two conductors $L1$ and $L2$ of the motor line. There are coupling inductances between all conductors of the motor line, where the intensity of the inductance depends not only on the current and frequency of the conductors, but also on the distance between them.

As shown in Figure 4.47, the distance between $L2$ and the protective conductor is higher than the distance of the other two conductors, the coupling inductance M_{L2PE} is lower than the other two inductances.




Figure 4.47: Inductive coupling in a motor line

Because the conductors $L1$, $L2$ and $L3$ induce currents of different intensity in the protective conductor -because of their different coupling inductances- the induced voltages do not compensate each other. Instead, they create a common voltage, which appears as a current flow in the protective conductor, as soon as it is connected several times to the equipotential bonding system. The current generated in the protective conductor causes potential differences in the equipotential bonding system. Experience has shown that the current flow may reach up to 10% of the phase currents.

4.5.2 Solutions from standards and specialist literature

As the motor line is an important part for CE certification, the frequency converter documentation usually specifies the cable type. This is, for example, the case in the documentation from Siemens [SIE2014], Danfoss [DAN2015], Lenze [LEN2015] and ABB [ABB2005]. All of these four vendors prescribe shielded motor lines. However, the structures of their motor lines differ in detail. The mentioned vendors are presented here as examples in order to allow for a better understanding. The list does not claim to be exhaustive. Lenze describes asymmetrical motor lines as shown in Figure 4.43 in its documents. ABB and Danfoss do not make any statement in their document about the type of motor line. Figure 4.48 shows an excerpt from the manufacturer documentation from Danfoss [DAN2015]. At ① you can see the connection line of the motor. It stands out that a separate protective conductor (PE) is to be implemented. At the connection point of the frequency converter, ② it becomes evident that the motor line has three phase lines and one cable shield only. The motor line in the figure does not have a protective conductor.




Figure 4.48: Typical installation of a frequency converter from [DAN2015]

Figure 4.49 shows an excerpt from a frequency converter documentation from ABB [ABB2005]. At the drive unit, you can see that a shielded motor cable ① is to be used for connection. It is, however, noticeable that the protective conductor of the drive unit does not run inside the shielded motor cable. This means a symmetrical motor line with a separate protective conductor is used in this case.




Figure 4.49: Drive with low voltage power supply from [ABB2005]

For a shielded motor line, a separate protective conductor as shown in Figure 4.48 and Figure 4.49 provides the advantage that no disturbances from inside the motor line can be coupled in the protective conductor.

Siemens provides in its document [SIE2014] a detailed description of the possible effects asymmetrical motor lines may have and recommends to use symmetrical three-phase current lines in order to ensure a better electromagnetic compatibility. As can be seen in Figure 4.50, symmetrical motor lines should have either three protective conductors inside the motor line or one protective conductor laid separately. When a motor line with three protective conductors is used, these conductors should be arranged symmetrically around the conductor lines $L1$ to $L3$. This considerably reduces the total of in-coupled voltages as the distances between the protective conductors and the corresponding conductor lines are equal.




Figure 4.50: Symmetrical motor lines as recommended by [SIE2014]

Another measure for the reduction of disturbances when using frequency converters is the usage of filters. However, the usage of filters is vendor-specific and, therefore not considered any further in this document.

4.5.3 Recommendations for PROFIBUS and PROFINET

In order to ensure safe plant operation, the load of the equipotential bonding system through voltages and currents coupled into it should be kept as low as possible. For this reason, the vendor instructions on how to connect the motor lines should be strictly observed. Symmetrical motor lines minimize inductive and capacitive coupling into the protective conductor of the motor line. As, however, coupling cannot be fully prevented, the motor and the frequency converter should be connected to the equipotential bonding system with a low-impedance connection. Due to this connection, it is possible that the currents caused by voltages coupled into the system can flow back via the equipotential bonding system and do not affect the data transfer via the PROFIBUS/PROFINET line. From this section of the document, the recommendation M5 is derived:

M5

- Use shielded motor cables in accordance with the manufacturer specifications and provide for big-surface connection of the shield to the common bonding network at each end (low impedance).
- Connect the motor to the common bonding network.
- If unshielded motor cables are used, provide filters at the inverter output.
- Connect the motor to the Common Bonding Network (CBN). See also chapter 4.3
- If not excluded by the manufacturer of the frequency converter, preferably use symmetrical shielded three-wire motor cables with separate protective conductor. See also chapter 4.5

- The instructions of the frequency inverter manufacturer should always be checked and followed.

4.6 Connecting the negative pole of 24 V power supply to the CBN

This section deals with the connection of the negative poles of 24 V power supplies to the common bonding network (CBN). Such a 24 V power supply is shown in Figure 4.51. In addition to the four remote I/O there is also a power supply unit in the figure.




Figure 4.51: 24 V power supply in a manufacturing plant

According to the [DIN-EN 60204-1] and [DIN-EN 60950-1] standards there are two permissible methods to set up the protective mechanisms in 24 V power supply circuits, and they are completely different.

The first variant consists in using SELV current circuits². In an emergency or in case of a fault, these current circuits carry only safety extra low voltage. For this reason, SELV current circuits are insulated from all other current circuits and from the common bonding system (CBN) of the plant. As a fuse in a SELV current circuit can be triggered only if there is a short-circuit between the positive and the negative pole, but not if a connection between the positive pole and the CBN exists, an insulation monitoring system must be provided to detect the connection to the CBN connection. Usually, such a monitoring system entails additional expenditure for the monitoring device and is therefore only used for special applications (e.g. in the oil and gas industry).

² SELV – Safety Extra Low Voltage

More often, however, PELV current circuits³ are used. Current circuits of this kind also provide for protection against electrical shock. In this case, however, it is required to connect the negative pole of the power supply to the CBN at least at one point close to the power supply unit. This allows, for example, that – in case of an insulation fault – the positive pole of the 24 V power supply unit gets in contact with the common bonding system, and a current circuit is formed. The resulting short circuit current triggers the fuse.

The connection of the negative pole to the common bonding network (CBN) is shown in Figure 4.52. This figure is a simplified representation of the manufacturing plant example in Figure 4.51 and can also be applied to the process industry. For the sake of simplicity, details such as fuses or terminals have been deliberately left out.




Figure 4.52: Simplified representation of a 24 V power supply circuit

³ PELV – Protective Extra Low Voltage

4.6.1 Problem description

Unwanted multiple connections of the negative pole with the CBN, usually cause problems. Accordingly designed devices may cause multiple connections to the CBN, for example. In the example in Figure 4.53, this additional connection to the CBN is present at the outmost remote I/O. Connections of this kind usually occur when the plant builders connect the minus current circuits of a plant section to the CBN without checking if a central connection to the CBN has already been installed.




Figure 4.53: Multiple connections to CBN in a 24 V power supply circuit

Due to multiple connections to the common bonding network (CBN) a parallel connection to the equipotential bonding system emerges. This connection with an undefined resistance is shown in Figure 4.53. The resistance of the equipotential bonding system is connected in parallel with the negative line of the 24 V power supply circuit. With this parallel connection, the following scenarios are possible:

- Scenario 1: The resistance of the equipotential bonding system is lower than the line impedance.
- Scenario 2: There is a break in the negative line.
- Scenario 3: The resistance of the equipotential bonding system is higher than the line impedance.

These three scenarios are further discussed in the following subsections.

4.6.1.1 Connection of 24 V power supply circuits to CBN, scenario 1

If the 24 V power supply circuit features multiple connections to the CBN, the total current is divided at the two connection points according to the Kirchhoff Current Law. This scenario is shown in Figure 4.54.




Figure 4.54: Connection 24 V power supply circuits to CBN, scenario 1

As, in this case, the resistance of the equipotential bonding system is lower than the impedance of the negative line, the major part of the total current flows through the equipotential bonding system. As a result, the equipotential bonding system is loaded with a direct current that should flow through the negative line of the power supply circuit. The cable shields of the data and motor lines are also connected to the equipotential bonding system at several points, so that the currents might also flow through them and damage them.

4.6.1.2 Connection of 24 V power supply circuits to CBN, scenario 2

If the negative line of the 24 V power supply circuit is interrupted as shown in Figure 4.55, the current is not divided at the multiple connection points to the CBN at the remote I/O, but completely returns to the power supply unit through the equipotential bonding system.




Figure 4.55: Connection of 24 V power supply circuits to CBN, scenario 2

If the total current completely returns to the power supply unit through the equipotential bonding system, this causes an additional load of the equipotential load system. Any load of the equipotential bonding system, be it direct current or alternating current, results in voltage drops. Moreover, shielded cables with low line impedance are in the equipotential bonding system; in order to ensure full functionality, they should be connected to the CBN at several points. As a result, however, current would also flow through the cable shield. These cable shields do not have high current ratings and are likely to be damaged by the current.

4.6.1.3 Connection of 24 V power supply circuits to the CBN, scenario 3

The third scenario is shown in Figure 4.56. Here, the resistance between the equipotential bonding system and the multiple connection points to the CBN is higher than the line impedance of the negative line. As a result, the currents are divided at the connecting points, as already described for scenario 1. In this case, however, a stray current from the equipotential bonding system flows through the 24 V power supply circuit. The reason why there is a stray current in the equipotential bonding system is further described in section 4.2.1.




Figure 4.56: Connecton of 24 V power supply circuits to CBN, scenario 3

The voltage drops produced by the stray current in the equipotential bonding system result in potential differences in the negative line. The consequence of these potential differences may be that the remote I/O unit is no longer supplied with the required mains voltage and fails. Furthermore, the stray current may be either a direct current or an alternating current, and this may cause various disturbance reactions.

4.6.2 Solutions from standards and technical literature

In the [DIN-EN 60204-1], the different types of connections to the CBN are specified. A 24 V power supply circuit has to be connected to the CBN at one end or at any point of the current circuit. In addition, the standard describes how the connection should be done. The connecting point should be located close to the power supply unit or directly next to, if possible, on the installation panel; it has to be easily accessible and must be disconnectable to allow for insulation measurements. If, however, a potential free 24 V power supply circuit with power supply unit is installed, an insulation measurement must be provided in the secondary circuit according to [DIN-EN 61557-8]. In the event of an alarm, it

may be used either for immediate disconnection or for outputting an optical and/or acoustic signal, depending on the risk level.

4.6.3 Recommendations for PROFIBUS and PROFINET

If a PELV current circuit is chosen for 24 V power supply, it should only be connected once to the functional equipotential bonding system/CBN directly at the power supply unit and using a disconnect terminal. When commissioning the 24 V power supply circuit, you can perform an insulation measurement and make sure that there is no additional connection to the equipotential bonding system. However, if you discover multiple connection points during this measurement, you will need to check if it is possible to remove them. Multiple connection points of 24 V power supply circuits with the CBN have to be avoided, due to the reasons described in Section 4.6.1.

Devices that have a fixed connection between functional bonding connector and the minus of the 24 V power supply circuit, create multiple connections of the 24 V power supply circuit with the CBN. In this case, the 24 V power supply circuit should have a small size, to limit the impact of a multiple connections to the CBN, described in section 4.6.1. It is also recommended to limit the size of a 24 V power supply circuit to the inner of cabinets or adjacent cabinets. A good equipotential bonding inside the cabinets and between cabinets has to be ensured. In case, 24 V power supply circuits cover larger distances, the effects described in section 4.6.1. have to be considered. A meshed equipotential bonding system with low impedance, as described in section 4.3.3. can reduce, but not eliminate, the impact of a multiple connections to the CBN.

If the multiple connections to the CBN result from internal connections inside the devices that are an integral part of the devices and cannot be removed. It may be necessary to provide a separate 24 V power supply circuit in this case. Multiple connections of 24 V power supply circuits to the CBN have to be avoided. In order to ensure that no multiple connections occur throughout long plant life-cycles, additional current monitoring of the connection to the CBN (see Figure 4.57) can be provided. The current monitoring equipment should be capable of measuring both direct currents and alternating current and of recognizing all potential operating faults that may result from possible future plant enhancements or from the replacement of devices.

Besides the grounded operation of 24 V power supply circuits a potential free operation is also permissible. In this case, a ground fault monitoring has to be provided.




Figure 4.57: Optimal earthing of 24 V power supply circuits

From this section of the document, the recommendation M6 is derived:

M6	<ul style="list-style-type: none">• Multiple connections of 24-V-Supply-Circuits to the common bonding network (CBN) have to be avoided.• In order to keep the cables between the power supply unit and the consumer as short as possible, it is recommended to use several smaller power supplies rather than a single big one.
----	---

5 Recommendations for the process industry

In the following, the recommendations elaborated in the previous chapter are transferred to the conditions of the process industry. Special features of the process industry are plants that are spread out over a large area and areas with explosive atmosphere.

In the case of a plant with a large area, special attention must be paid to the maximum cable length of PROFIBUS and PROFINET cables. Fiber optic cables can provide a remedy here. In order to implement the applicable explosion protection measures, various types of protection are defined to prevent equipment from becoming a source of ignition. The ignition protection type "increased safety" (Ex e) is important for this document. This requires that the equipment must have measures in place to prevent the formation of hot surfaces, sparks or electric arcs. The ignition protection type "intrinsic safety" (Ex i) is also of interest. To implement this protective measure, the available electrical energy in an electric circuit is limited so that sparks or heat generation cannot cause ignition.

The effects of explosion protection on EMC measures are particularly relevant in the following areas:

- Equipotential bonding: See chapter 5.3
- Support of cable shields: See chapter 5.4
- Shielding of motor cables: See chapter 5.5

In the following chapters, the aspects that must be considered in particular in the process industry will now be dealt with in detail.



Note for areas with explosive atmosphere: The devices used must be certified for the use in the respective Ex-Zone. Respective Ex certificates / manufacturer declarations must be available and checked during the planning process. An Ex risk analysis must be executed and documented during the planning process according to the national legislation.



This chapter explains only special planning aspects for PROFIBUS and PROFINET Networks. It does not show the full scope of planning for Ex-installations.

A plant example for the process industry is shown in Figure 5.1.




Figure 5.1: Plant example from the process industry

The plant shown in Figure 5.1 has two vessels that are filled and emptied by pumps ⑤ and valves ⑥. A low voltage main distributor ① (LVMD) is used for power supply to the plant. It supplies the cabinet that accommodates the frequency converter ② and the programmable logical controller ③ (PLC). Additionally, the plant comprises two decentralized remote I/O units ④ controlling the sensors and actuators. In this plant example, you can see an exemplary presentation of the following problems: Control of drives/actuators, wide-spread plants and automation equipment distributed in the field.

5.1 Connection of protective and functional equipotential bonding

Also, in the process industry, the strict separation of protective and functional equipotential bonding is not possible, which is why a combined protective and functional equipotential bonding is recommended as in chapter 4.1.

P1

Provide both protective equipotential bonding and functional equipotential bonding through a common bonding network (CBN).

5.2 Structure of the 230V/400V mains supply

In general, the recommendations described in chapter 4.2 can be transferred from the manufacturing to the process industry. In areas with explosive atmosphere, however, there are restrictions regarding the power supply system.

According to [DIN-EN 60079-14], the TN version of system earthing in areas with explosive atmosphere is only permitted as a TN-S system, see chapter 4.2. If it is a TN-C-S system, the PEN must be divided into PE and N conductors according to [DIN-EN 60079-14] at the latest during the last distribution before the area with explosive atmosphere. In this case, the recommended action of the manufacturing industry can be transferred to the process industry. A TN-S structure must always be provided in areas with explosive atmosphere.

P2

Preferably use a 230/400 V power supply using a TN-S system. Use a TN-S system in the area with explosive atmosphere in any case.

5.3 Equipotential bonding system

The recommendations from chapter 4.3 can be largely transferred to the process industry, whereby further points must be observed in the area with explosive atmosphere.

Good equipotential bonding is also important in the Ex area, as it ensures that no dangerous voltages are present on any electrical equipment that could lead to the generation of an explosive spark. For this reason [DIN-EN 60079-14] requires equipotential bonding in areas with explosive atmosphere. Furthermore, all electrical equipment and external conductive parts in the area with explosive atmosphere must be connected to the equipotential bonding. The connections must be secured against self-loosening and their risk of corrosion must be reduced to a minimum, as this can reduce the effectiveness of the connections.

A closely meshed equipotential bonding as shown in Figure 4.30 exhibits only small voltage differences due to its low impedance. This reduces the size of equalizing currents, which can flow through cable shields, for example. This problem is discussed further in chapter 5.4. Including the horizontal and vertical reinforcement of the building and the metal construction of the production plant can further improve equipotential bonding.

A measurement of the shield current can give an indication of the quality of the shield connection and the grounding. A low shield current, considering the shield impedance, indicates good grounding and shielding. At present, however, the necessary procedures must be determined individually by the user, considering the system conditions. The measurement can be carried out without interruption and with spatial flexibility using a current clamp. The timely detection of excessive shield currents can prevent greater damage. Since the current clamps are not intrinsically safe, shield current measurements may not normally be carried out in Ex areas without a written work permit by the management.

If there is separate equipotential bonding between plant sections, it is not recommended to connect them via shielded signal cables (Figure 5.2).




Figure 5.2: Copper cable between plant sections

Since it cannot be ensured that the connected points in CBN1 and CBN2 have the same potential, an undesirable compensating current may flow via the cable shield. This interferes with the signal transmission and can also be a source of danger in areas with explosive atmosphere.

This can be remedied by signal transmission via optical fibres, as these transmit data without connecting the earthing systems with each other (Figure 5.3).




Figure 5.3: Fiber-Optic cable between plant sections

If the separated equipotential bonding systems are only a short distance apart, a connection may for example be created by conveyor equipment, pipe bridges or in plants of the process industry possibly by persons. In this case, it is recommended to set up a connected equipotential bonding system as shown in Figure 5.4.




Figure 5.4: Continuous meshed CBN between plant sections

A similar problem can also be observed between areas with and without explosive atmosphere. If there are separate equipotential bonding systems inside and outside the Ex-area, cables connecting both areas and whose shields are only connected to the equipotential bonding outside the Ex-area represent a potential source of sparks inside the Ex-area. This is because the shield in the Ex-area has the potential from outside. When a conductive connection is made, a compensating current may flow and sparks may be generated. According to [DIN-EN 60079-14], the separate equipotential bonding systems must therefore be connected. For this reason, it is advisable to plan from the outset for continuous, meshed equipotential bonding inside and outside the area with explosive atmosphere. Further details on the structure of the meshed equipotential bonding system can be found in chapter 4.3.

P3	<ul style="list-style-type: none">• Design combined equipotential bonding system (Common Bonding Network CBN) as finely meshed as possible (MESH-BN).• Provide Potential separation or a continuous CBN between hall boundaries.• Provide continuous CBN inside and outside the area with explosive atmosphere.• In areas with explosive atmosphere, safely connect electrical and external conductive parts with CBN.
----	---

5.4 Connection of the PROFIBUS and PROFINET cable shields

For the reasons mentioned in chapter 4.4 regarding the improved shielding effect, the shield of PROFINET cables should also be grounded at both ends in plants in the process industry. Within the area with explosive atmosphere, however, the recommendations depend on further considerations.

As shown in Figure 4.24 currents in the CBN sometimes also flow through cable shields that are connected on both sides. The larger the meshes and the currents through them, the greater the risk of generating sparks when opening the cable shield. Opening cannot be prevented, as for example damage to the cable can lead to opening of the shield. In addition, the conversion of field devices in areas with explosive atmosphere is permitted during plant operation as long as the devices support the type of protection "intrinsically safe" (Ex i). In this case, their signal lines do not carry enough energy to act as ignition sources. However, this does not apply to their shields. For these reasons, the case of shielding on both sides shown in Figure 5.5 can represent a danger in the Ex area.




Figure 5.5: Grounding of cable shield on both sides in areas with explosive atmosphere for PROFIBUS PA

One solution to this problem is to minimize shield currents by minimizing currents in the equipotential bonding. According to [DIN-EN 60079-14], grounding the cable shield on both sides in the Ex-area is only permissible if "it is highly ensured that equipotential bonding exists between each end of the circuit". The document does not specifically prescribe what makes equipotential bonding highly safe. In chapter 5.3 steps that contribute to improving equipotential bonding are listed as a guide.

The additional connection of the cable shield to the CBN upstream of a PROFINET device (Figure 4.40) or multiple shield contacting (Figure 4.41) are very well suited to avoid the risk of generating sparks when the device is disconnected, since in this case the shield current can flow via the connection before the device. However, these connections between shield and CBN are often practically impossible, as the insulation has to be peeled off for this purpose and the cable is thus exposed to environmental influences.

If the currents in the equipotential bonding cannot be minimized, i.e. the equipotential bonding is not ensured to a high degree, the current flow from the equipotential bonding via the shield must be prevented. [DIN-EN 60079-14] prescribes in this case a one-sided shield connection or two-sided shield connection with capacitor at one end (Figure 5.6). In the latter case, the capacitor must not be larger than 10 nF, otherwise it represents a safety risk. Due to this restriction, the capacitor can usually not be designed large enough to allow the currents required for active shielding to flow via the shield. In this case, the double-sided shield connection with capacitor at one end behaves like the single-sided shield connection, meaning that in both cases the shielding effect against magnetic fields doesn't exist. If necessary, this disadvantage can be compensated by increasing the distance between the PROFINET cable and the power cable.




Figure 5.6: Grounding of cable shield on both sides with capacitor in areas with explosive atmosphere

The shielding end of a single-sided shield has to be insulated to prevent contact with a conductive surface, as this can lead to generation of sparks (Figure 5.7). This risk depends on the quality of the equipotential bonding, as the potential at the connected end of the shield is, in the worst case, significantly different from that at the other end.




Figure 5.7: Ignition hazard due to insulation faults and poor equipotential bonding

Table 5.1 shows different connection possibilities of the cable shield with the CBN in the area with explosive atmosphere. Since the shield grounding on both sides in areas with explosive atmosphere is only permitted according to [DIN-EN 60079-14] if equipotential bonding is ensured to a high degree, a meshed CBN is assumed in this case. Therefore, a low shield current and a small voltage difference between the shield end and the CBN can be assumed. In the other two cases a less good equipotential bonding is assumed.



This chapter explains only special planning aspects for PROFIBUS and PROFINET Networks. It does not show the full scope of planning for Ex-installations.

Table 5.1: Connection possibilities of cable shield and CBN in areas with explosive atmosphere

	One-sided connection with CBN	Connection with CBN via capacitor	Connection on both sides with meshed CBN
Allowed by standard	✓	For total capacity < 10 nF per shielding segment	If equipotential bonding is ensured to a high degree
Protection against capacitive influences	✓	✓	✓
Protection against inductive influences	X	Only for very high frequency inductive influences	✓
No danger of ignition due to shield current in normal operation	✓	✓	✓
Danger of ignition in case of insulation faults	High	High	Low

Recommendation P4 can be derived from the explanations given so far.

P4	<ul style="list-style-type: none"> • Provide a connection of the PROFIBUS/PROFINET cable shields through the housings of the connectors and through the housings of the devices and thus to the common bonding network (CBN) at each cable end with big contact surfaces (low impedance). • In areas with explosive atmosphere, if equipotential bonding is not ensured to a high degree, connect shield at one end or both ends with capacitor (max. 10 nF) at one end.
----	--

5.5 Motor cables

In principle, the recommendations in 4.5 also apply to the process industry. However, there are further procedures regarding the use of shielded motor cables. The NAMUR advises against the use of shielded motor cables in NE108. The reasons given include the increased cable capacity of shielded motor cables and the resulting reduced maximum cable length. Reference is also made to a more demanding installation when connecting the cable shields and increased harmonic currents. Instead, the NAMUR in NE 38 recommends the use of filtering measures at the inverter output in conjunction with unshielded motor cables. The use of filters is usually not the first choice in the manufacturing industry, as they have a negative effect on the energy efficiency of the drive solution.

For the Ex-area motor cables must fulfil the type of protection "increased safety" (Ex e), i.e. the connections are protected against vibration and heating. Due to the risk of generating sparks, the cable must not be disconnected during operation and, if a shielded motor cable is used, the proper shield connection must be ensured, as currents that cannot be ignored also flow through the shield.

P5

- Use shielded motor cables and provide for large-surface connection of the shield at each end to the common bonding network (CBN) with low impedance, ensure proper shield connection in the Ex-area.
- If unshielded motor cables are used, provide filters at the inverter output. See also the recommendations of NAMUR Guideline NE 108.
- Connect the motor to the Common Bonding Network (CBN). See also chapter 4.3
- If not excluded by the manufacturer of the frequency converter, preferably use symmetrical shielded three-wire motor cables with separate protective conductor. See also chapter 4.5
- The instructions of the frequency inverter manufacturer should always be checked and followed.

5.6 Connection of the negative pole of a 24 V supply to the CBN

In the process industry, multiple connections of 24 V supply circuits to the CBN should be avoided for the same reasons mentioned in chapter 4.6. In areas with explosive atmosphere, the 24 V supply circuits are partly intrinsically safe. In this case, multiple connections with the CBN according to [DIN-EN 60079-14] are prohibited.

P6

- Multiple connections of 24 V circuits with the Common Bonding Network (CBN) have to be avoided and are not permitted in the Ex-area.
- In order to keep the cables between the power supply unit and the consumer as short as possible, it is recommended to use several smaller power supplies rather than a single big one. See also chapter 4.6

6 Summary of the recommendations for the design of PROFIBUS and PROFINET networks with little disturbance

The following sections summarize the recommendations for action for the manufacturing and process industry. Section 6.1 outlines the manufacturing industry, while section 6.2 considers the process industry.

The six recommendations M1 to M6 and P1 to P6 help to avoid disturbances by electromagnetic interference in a plant with PROFIBUS and PROFINET networks. The measures, proposed in this document have to be synchronized between planner, installer and operator of the plant. When planning a system, be sure to consider all recommendations if possible. Any later plant adaptation that may become necessary in ongoing operations due to disturbances caused by electromagnetic interference implies heavy additional expenditure.

Therefore, power supply systems in new or modernized plants should be designed as TN-S systems only. The TN-S system prevents operating currents from the neutral conductor to enter the equipotential bonding system as there is only a connection between the protective conductor and the neutral conductor in the LVMD. As a result, current flows that may cause potential differences in the equipotential bonding system are avoided.

When implementing such a system, you can also provide for common protective and functional equipotential bonding, as it is no longer possible to ensure consistent separation of these two equipotential bonding systems in modern plants. If a common bonding network (CBN) is used, make sure that it meets the requirements on proper protective and functional earthing. The equipotential bonding system must feature a sufficient capacity and low impedance. For the sake of electromagnetic compatibility, the connections should be protected against unintentional loosening and adverse weather conditions.

Optimal low-impedance equipotential bonding can be achieved by using a meshed equipotential bonding system in compliance with DIN EN 50310. A meshed equipotential bonding system features a multitude of small meshes that reduce the impedance. Low impedance reduces the occurrence of potential differences caused by coupling.

In addition, the cable shields of PROFIBUS and PROFINET lines should be connected to the equipotential bonding system at least at both ends. The connection should be made through the connector plug of the PROFIBUS/PROFINET device. The connection between the connector shroud and the functional earth connector should also have a low

impedance. Additionally, there should be further connections between the cable shields and the equipotential bonding system in order to reduce the size of the meshes for coupling (see section 4.4.1).

Currents in the equipotential bonding system could also be caused by the motor lines. Inside the motor lines, inductive and capacitive coupling may generate current. This can be avoided by using shielded motor lines, which in fact are already prescribed by the vendors of the corresponding frequency converters.

When implementing 24 V power supply circuits, multiple earthing should basically be avoided. Multiple earthing of the negative pole in a 24 V power supply circuit may allow currents from the equipotential bonding system to reach into the 24 V power supply circuit and cause potential shifts. These potential shifts may result in the failure of units when the voltage falls below their rated voltage. Moreover, currents from the 24 V power supply circuit may reach into the equipotential bonding system. This system, however, also comprises cable shields which do not feature a sufficiently high ampacity and will heat with increasing current. This means that multiple earthing of a 24 V power supply circuit may present a fire hazard (see section 4.6.1.3). In order to avoid this, 24 V power supply circuits should be earthed only once through the equipotential bonding system. A simple monitoring function established by implementing a current monitor at the single earthing point allows you to identify multiple earthing of the 24 V power supply circuit during on-going plant operation.

6.1 Manufacturing Industry

M1	Provide both protective equipotential bonding and functional equipotential bonding through a common bonding network (CBN).
M2	Preferably realize 230/400 V power supply using a TN-S system.
M3	Design combined equipotential bonding system (Common Bonding Network CBN) as finely meshed as possible (MESH-BN).
M4	Provide a connection of the PROFIBUS/PROFINET cable shields through the housings of the connectors and through the housings of the devices and thus to the common bonding network (CBN) at each cable end with big contact surfaces (low impedance).
M5	<ul style="list-style-type: none"> • Use shielded motor cables in accordance with the manufacturer specifications and provide for big-surface connection of the shield at each end to the common bonding network (CBN) with with low impedance. • Connect the motor to the common bonding network (CBN). • If unshielded motor cables are used, provide filters at the inverter output. • If not excluded by the manufacturer of the frequency converter, preferably use symmetrical shielded three-wire motor cables with separate protective conductor. • The instructions of the frequency converter manufacturer should always be checked and followed.
M6	<ul style="list-style-type: none"> • Multiple connections of 24-V-Supply-Circuits to the common bonding network (CBN) have to be avoided. • In order to keep the cables between the power supply unit and the consumer as short as possible, it is recommended to use several smaller power supplies rather than a single big one.

6.2 Process Industry

With regard to the process industry, plant that are spread out over a large area and possible restrictions due to areas with explosive atmosphere must also be considered. The resulting facts are explained in more detail in chapter 5.

P1	Provide both protective equipotential bonding and functional equipotential bonding through a common bonding network (CBN).
P2	Preferably use a 230/400 V power supply using a TN-S system. Use a TN-S system in the area with explosive atmosphere in any case.
P3	<ul style="list-style-type: none"> • Design combined equipotential bonding system (Common Bonding Network CBN) as finely meshed as possible (MESH-BN). • Provide Potential separation or a continuous CBN between hall boundaries. • Provide continuous CBN inside and outside the area with explosive atmosphere. • In areas with explosive atmosphere, safely connect electrical and external conductive parts with CBN.
P4	<ul style="list-style-type: none"> • Provide a connection of the PROFIBUS/PROFINET cable shields through the housings of the connectors and through the housings of the devices and thus to the common bonding network (CBN) at each cable end with big contact surfaces (low impedance). • In areas with explosive atmosphere, if equipotential bonding is not ensured to a high degree, connect shield at one end or both ends with capacitor (max. 10 nF) at one end.
P5	<ul style="list-style-type: none"> • Use shielded motor cables and provide for large-surface connection of the shield at each end to the common bonding network (CBN) with low impedance, ensure proper shield connection in the Ex-area. • If unshielded motor cables are used, provide filters at the inverter output. See also the recommendations of NAMUR Guideline NE 108. • Connect the motor to the Common Bonding Network (CBN). See also chapter 4.3

	<ul style="list-style-type: none">• If not excluded by the manufacturer of the frequency converter, preferably use symmetrical shielded three-wire motor cables with separate protective conductor. See also chapter 4.5• The instructions of the frequency inverter manufacturer should always be checked and followed.
P6	<ul style="list-style-type: none">• Multiple connections of 24 V circuits with the Common Bonding Network (CBN) have to be avoided and are not permitted in the Ex-area.• In order to keep the cables between the power supply unit and the consumer as short as possible, it is recommended to use several smaller power supplies rather than a single big one. See also chapter 4.6

7 Shield Current Measurement

In the following chapters, the shielding current and loop impedance measurements are discussed as part of an acceptance test. Shield current and loop impedance are important aspects for the EMC resistance of the system.

7.1 Importance of shield currents

Shield currents have various causes. On the one hand, shield currents are induced by magnetic fields of parallel-running power lines, but on the other hand, stray currents from power distributions can also flow via cable shields. In addition, shield currents also occur via asymmetrically constructed power / motor cables. Here, a voltage is induced in the PE conductor in the motor cable. This leads to a current flow through the PE conductor and a corresponding reverse current via the equipotential bonding system and the cable shields. These causes of shield currents are considered below.

Chapter 3.1.2 explains that a shield current is required for the active shielding effect against magnetic fields. Figure 7.1 shows an energy line running parallel to the signal line. The magnetic field of the energy line induces a voltage in the line shield. Provided that both sides of the line shield are connected to the equipotential bonding system, this results in a current in the shielding loop which largely eliminates the magnetic field inside the cable shield and thus protects the signal lines. For this reason, cable shields should be connected on both sides to the equipotential bonding system, if possible.




Figure 7.1: Current through shield loop, required for active shielding effect against magnetic fields

However, the current on shields can also be caused by vagabonding currents in the CBN, as described in chapter 4.3. A current flowing through the CBN splits between the equipotential bonding conductor and the shield and thus also flows partially across the shield (Figure 7.2).




Figure 7.2: Distribution of current between equipotential bonding conductor and signal line

The shield current is therefore composed of a required and a disturbing component. Unfortunately, the two shield current components can hardly be distinguished by measurement. Therefore, in general the currents on line shields should be as low as possible. This is achieved, for example, by keeping a minimum distance between energy and signal lines, reducing vagabonding currents in the equipotential bonding system, e.g. by the use of symmetrical energy and motor lines, or using TN-S energy distributions and constructing the equipotential bonding in the form of a meshed CBN.

7.2 Shield current measurement

Figure 7.3 represents two automation components whose housings are respectively connected to the CBN and the signal line shield. A current clamp can be used to measure the current on signal line shields or on equipotential bonding conductors. A brief description of the characteristics of such a current clamp can be found in Appendix A1 Current Clamp Recommendations. By measuring the resulting magnetic field, both the shield current and the current on the signal lines are measured, although the latter can usually be neglected. For applications with higher EMC exposure, such as in a switchboard cabinet, a shielded clamp is recommended so that only the current in the conductor surrounded by the clamp is actually measured.




Figure 7.3: Measurement of shield current with current clamp

It is recommended to measure the shield currents of the PROFIBUS / PROFINET lines while the system is running. If the shield current is present but does not exceed a certain maximum value, it can be concluded that the EMC load on the signal lines due to the shield current is not too high and that the equipotential bonding has a sufficiently low impedance.

Acceptable values for shield currents depend, among other things, on the cable types used, the automation components used and the signal form of the shield currents (frequency, edge steepness). For this reason, no fixed specifications can be made. The values in Table 7.1 are based on the experience of the companies participating in the working group, but do not represent binding maximum values.

Table 7.1: Measures to be taken in case of excessive shield currents (guide values)

Measured shield current Recommended measure
with shield applied at
both ends

< 5 mA	Very good value, to be aimed at especially for Ex plants.
< 30 mA	No action required outside Ex area.
30 mA ... 100 mA	Check cause and reduce value below 30 mA if possible.
> 100 mA	Action required: Eliminate source of interference, mesh equipotential bonding, reduce stray currents, increase distance between power lines and bus lines if necessary.



Relevant directives, e.g. for potentially explosive atmospheres, must be minded. These directives may prescribe other limit values.

If only a very small shield current is measured, this indicates either a very good shield connection and a very good equipotential bonding and large distances between the bus line and power lines or possibly an interruption of the shield circuit or poor contacting of the shield. Often this interruption can be found at the device connectors or in the device itself. Small currents can also flow purely capacitively when the shield is connected on one side. A loop impedance measurement is suitable for checking that a low-impedance, double-sided shield connection is present. See chapter 7.5.

7.3 Remedial measures for excessive shield currents

If the selected maximum value of the shield current is exceeded, the cause should be determined and eliminated to increase the EMC resistance. Examples are:

- Reduction of vagabonding currents
- Increase distance power lines to signal lines
- Use of symmetrical and/or shielded power and motor cables
- Improvement of an insufficient potential equalization.

In case of insufficient equipotential bonding, the CBN should be extended according to chapter 4.3. The recommended meshed equipotential bonding reduces the interference

currents to a minimum, since it represents a significantly lower impedance than the shield and thus also carries the major part of the current.

It should be noted that meshing the equipotential bonding reduces the effects of stray currents, but does not eliminate the root cause. The measures in Table 7.2 on the other hand, eliminate the causes of an operational current in the equipotential bonding.

Table 7.2: Further remedial measures to lower the currents in equipotential bonding

Possible cause	Recommended measure	Chapter
Mains supply designed as TN-C system	Switch to TN-S system	4.2
TN-S system with multiple connections between N and PE	Search for multiple connection of N and PE and disconnect excess connections	4.2.1.3
24 V systems with multiple connections at the negative terminal	Search for multiple connection between negative terminal and CBN and disconnect excess connections	4.6
Unbalanced or unshielded power/motor cables	Use of shielded and/or balanced power and motor cables	4.5

7.4 Meaning of the loop impedance

The ohmic part of the impedance of the shield loop consists of the shield resistance, the resistance of the equipotential bonding conductors and the resistances of the contacting and grounding of the shield within the devices. The loop impedance must be small enough to allow the flow of a sufficient shield current to achieve the active shielding effect according to chapter 3.1.2. For example, poor contacting of the cable shield in the connector or poor contacting of the device housing with the equipotential bonding can increase the loop impedance to such an extent that the shield current is no longer large enough to revert the incident magnetic field. To take these cases into account, the loop impedance should also be measured in addition to the shield current.

7.5 Loop impedance measurement

For further analysis, a loop impedance clamp can be used as shown in the Figure 7.4. This allows the resistance of a loop to be measured without having to disconnect the line. It induces a voltage into the considered circuit and measures the resulting current to determine the impedance of the loop. Usually, these devices can also divide the measured impedance into ohmic and inductive resistance. In case of a good equipotential bonding and a low impedance shield connection at the device, the ohmic part of the loop impedance would correspond approximately to the shield resistance, because the resistance of the potential equalization is usually negligible. The shield resistance of a PROFIBUS / PROFINET cable is approx. 10 15 mΩ /m (approximate value). If the measuring clamp displays a significantly higher value depending on the cable length, or signals that this is outside the measuring range, no sufficient shielding current is possible, meaning that shielding against inductive coupling is not possible.




Figure 7.4: Loop impedance measurement

7.6 Remedy for excessive loop impedance

The part of the loop which greatly increases the impedance must first be located so that the error can be corrected. Table 7.3 documents various error causes and gives suggestions for solution measures.

Table 7.3: Remedial measures for excessive loop impedance

Cause	Recommended measure
Cable shield in the device connector not correctly contacted	Renew contacting and ensure low impedance connection
Contacting of the shield in the device or the connector housing with the device insufficient	Additional connection of the cable shield to the CBN directly in front of the device with an external shield clamp (Figure 4.4)
Shield interrupted	Replace shield connection / bus line
Equipotential Bonding is insufficient	Extend CBN according to chapter 4.3, lay equipotential bonding conductor close to signal line



Note for areas with potentially explosive atmospheres: The devices used must be certified for use in the respective Ex zone. Corresponding Ex certificates / manufacturer's declarations must be available and checked during planning. An Ex risk analysis must be carried out and documented according to national legislation during the planning process.



This chapter only explains special planning aspects for PROFIBUS and PROFINET networks. It does not show the full scope of aspects for Ex installations.

8 Suggestions for possible acceptance tests

It is recommended, for future acceptance tests of PROFIBUS or PROFINET systems, to also consider their electromagnetic compatibility. To be sure, to remember the essential points, you should use a checklist as shown in Table 8.1. The table has the same layout as the checklists suggested in the Installation Guideline for Commissioning from PROFIBUS User Organization.

Table 8.1: Suggestions for possible acceptance tests

Plant		Installation made by		
		Comments		
EMC checklist				
No.	Check request	YES	NO	Comment
1.	Mains supply			
1.1	Mains supply network preferably implemented as TN-S system?			
1.2	PEN bridge provided in LVMD?			
1.3	No other PEN bridges installed?			
1.4	Insulation test between neutral conductor and protective conductor performed with open PEN bridge?			
1.5	Current monitoring provided at PEN bridge? (optional)			
No.	Check request	YES	NO	Comment
2.	Equipotential bonding system			
2.1	Common protective and equipotential bonding network (CBN) installed?			
2.2	Meshed equipotential bonding system installed?			
2.3	Tin-plated copper strand used to ensure low impedance of the equipotential bonding system?			
2.4	Is the current rating of the equipotential bonding conductor sufficient?			
2.5	Potential separation between area boundaries or continuous CBN provided?			
3.	Connection of PROFIBUS/PROFINET cable shields			
3.1	Is a good connection of the connector housings to the housing of the PROFIBUS / PROFINET devices and thus a good connection to the CBN achieved?			
3.2	Do the used connector plugs have sufficiently big contact surfaces for the cable shields?			
3.3	Does the cable shield feature a low-impedance connection to the equipotential bonding system?			

4.	24 V power supply circuits			
4.1	Is the 24 V power supply circuit connected to the CBN??			
4.2	Is the connection of the negative pole in the 24 V power supply circuit to the CBN located close to the power supply unit?			
4.3	Is the 24 V power supply circuit connected only once to the CBN?			
4.4	Was the insulation test between earth and the CBN system performed with open earth connector?			
4.5	Is current monitoring of CBN connection provided (optional)?			
4.6	Where a multiple earth connection of a 24 V supply circuit to the CBN is present: Is the spatial extent of the 24 V supply circuit limited?			
4.7	Where a multiple connection of a 24 V supply circuit to the CBN is present: Is a low impedance of the CBN ensured?			
5.	Cables outside cabinets laid in cable trays			
5.1	Data lines laid separately from power supply lines?			
5.2	Minimum distances according to [DIN-EN 50174-2] and [IEC 60364-4-44] observed? If required, [NE 98] should be observed for application in the process industry			

No.	Check request	YES	NO	Comment
6.	Motor lines			
6.1	Are motor cables according specification of the manufacturer of the frequency converter in use?			
6.2	Are the motors connected to the CBN?			
6.3	Recommended for the sake of EMC if not excluded by the manufacturer of the frequency converter: Were shielded symmetrical motor lines or shielded three-wire motor lines with separate protective conductor used?			
6.4	If unshielded motor cables are used, are filtering measures provided at the inverter output?			

No.	Request	YES	NO	Comment
7.	Areas with explosive atmosphere			
7.1	230/400 V mains supply set up as TN-S system?			
7.2	Electrical equipment and conductive parts safely connected with CBN?			
7.3	Optional: Reinforcement of the building included in CBN?			
7.4	CBN inside and outside the area with explosive atmosphere, meshed and connected?			
7.5	Quality of equipotential bonding checked via shield current measurement?			
7.6	If equipotential bonding is not ensured to a high degree: Cable shields connected on one or both sides with capacitor (max. 10 nF)?			
7.7	Open ends insulated from cable shields on one side?			
7.8	Multiple connections of 24 V circuits with CBN prevented?			
7.9	Connections of motor cables secured against vibration and heating? Professional shielding?			

No.	Request	YES	NO	Comment
8.	Shield Current Measurement			
8.1	Is the shield current on all signal lines below the recommended maximum value?			
8.2	Has a loop impedance measurement been performed for all signal lines?			

9 Literature

- [ABB2005] ABB: EMV gerechte Installation und Konfiguration eines Antriebs-Systems, 2005.
- [APL2021] Niemann, K.-H.: Ethernet APL Engineering Guideline. Planning, installation and commissioning of Ethernet-APL networks. <https://www.profi-bus.com/download/engineering-guideline-ethernet-apl>.
- [DAN2015] Fredstedt, J.: Wissenswertes über Frequenzumrichter, 2016.
- [DEH2016] Dehn: Erdungsfestpunkte. <https://www.dehn.de/de/197/4785/Familie-html/4785/Erdungsfestpunkte.html>, 13.01.16.
- [DIN 18014] DIN 18014: März 2014, Fundamentender - Planung, Ausführung und Dokumentation.
- [DIN-EN 50174-2] 50174-2:2015-02, Informationstechnik -Installation von Kommunikationsverkabelung- Teil 2: Installationsplanung und Installationspraktiken in Gebäuden.
- [DIN-EN 50310] DIN EN 50310:01.05.2011, Anwendung von Maßnahmen für Erdung und Potenzialausgleich in Gebäuden mit Einrichtungen der Informationstechnik.
- [DIN-EN 60079-14] 60079-14:2014-10, Explosionsgefährdete Bereiche - Teil 14: Projektierung, Auswahl und Errichtung elektrischer Anlagen
- [DIN-EN 60204-1] 60204-1:10.2014, Sicherheit von Maschinen -Elektrische Ausrüstung von Maschinen.
- [DIN-EN 60950-1] DIN EN 60950-1:August 2014, Einrichtungen in der Informationstechnik - Sicherheit - Teil 1: Allgemeine Anforderungen.
- [DIN-EN 61557-8] 61557-8:12.2007, Elektrische Sicherheit in Niederspannungsnetzen bis AC 1000 V und DC 1500 V.
- [DIN-EN 61918] DIN EN IEC 61918 VDE 0800-500:2019-12 Industrielle Kommunikationsnetze
- [DIN-EN 62305-4] DIN EN 62305-4:Oktober 2011, Blitzschutz - Teil 4: Elektrische und elektronische Systeme in baulichen Anlagen.

- [DIN-VDE 0100-100] DIN VDE 0100-100:Juni 2009, Errichten von Niederspannungsanlagen – Teil 1: Allgemeine Grundsätze, Bestimmungen allgemeiner Merkmale, Begriffe.
- [FAB2010] Faber, Ulrich; Grapentin, Manfred; Wettingfeld, Klaus: Prüfung elektrischer Anlagen und Betriebsmittel - Grundlagen und Methoden. Allgemeine Rechtsgrundsätze, EG-Richtlinien, GPSG, BetrSichV, EnWG, BGV A3, TRBS, DIN VDE 0100, DIN VDE 0105-100, DIN IEC 60038 (VDE 0175), DIN EN 60204-1 (VDE 0113-1), DIN EN 61340 (VDE 0300), DIN EN 61010 (VDE 0411), DIN EN 61557 (VDE 0413), DIN VDE 0701-0702, DIN EN 61000-2/-6 (VDE 0839-2/-6), DIN EN 61000-4 (VDE 0847-4), DIN EN 60051. VDE-Verl., Berlin, 2010.
- [GAI2015] Gaiser, M.: Email, Bremen, 2015.
- [GÖH2015] Göhringer, H.-L.: Technische Strategie Sitzung 2015. Status-Bericht der Troubleshooting Arbeitsgruppe, 2015.
- [IEC 60364-4-44] DIN VDE 0100-444:Oktober 2010, (DIN VDE 0100-444) Errichten von Niederspannungsanlagen - Teil 4-444: Schutzmaßnahmen - Schutz bei Störspannungen und elektromagnetischen Störgrößen (IEC 60364-4-44).
- [IEC 60364-5-54] 0100-540:Juni 2012, Errichten von Niederspannungsanlagen - Teil 5-54: Auswahl und Errichtung elektrischer Betriebsmittel - Erdungsanlagen und Schutzleiter (DIN-VDE 0100-540); Deutsche Übernahme HD 60364-5-54:2011.
- [KLE2016] Kleinwächter: Elektrostatische Aufladung verstehen und sicher messen. http://www.kleinwaechtergmbh.de/cms/upload/downloads/allgemein/ESD_Anleitung.pdf, Stand: 18.01.16.
- [LEN2015] Lenze SE: Gerätehandbuch L-force Drives 9400, 2015.
- [NE 98] NAMUR-Arbeitskreis 4.6 „EMV“: EMV-gerechte Planung und Installation von Produktionsanlagen, Leverkusen, 2007.
- [NIE2017] Niemann, K.-H.: Produkt: Indu-Sol, Foto: Niemann. Email, 2017.
- [PRO2022] PROFIBUS Nutzerorganisation e.V.: PROFINET Montagerichtlinie, Karlsruhe, 2022.
- [PRO2020] PROFIBUS Nutzerorganisation e.V.: PROFIBUS. Montagerichtlinie. 2020.

- [RUD2011] Rudnik, S.: EMV-Fibel für Elektroniker, Elektroinstallateure und Planer. Maßnahmen zur elektromagnetischen Verträglichkeit nach DIN VDE 0100-444:2010-10. VDE-Verl., Berlin [u.a.], 2011.
- [SCH2008] Schmolke, H.: EMV-gerechte Errichtung von Niederspannungsanlagen. Planung und Errichtung elektrischer Anlagen nach den Normen der Gruppen 0100 und 0800 des VDE-Vorschriftenwerks. VDE-Verl, Berlin, 2008.
- [SIE2014] Siemens: SINAMICS - Low Voltage Projektierungshandbuch. SINAMICS G130, G150, S120 Chassis, S120 Cabinet Modules, S150. <http://w3app.siemens.com/mcms/infocenter/dokumentencenter/ld/InfocenterLanguagePacks/sinamics-projektierungshandbuch-lv/sinamics-projektierungshandbuch-lv-de.pdf>, Stand: 26.11.15.
- [SIE2016] Siemens AG: SIMATIC NET Industrial Ethernet / PROFINET Passive Netzkomponenten. Systemhandbuch, 2016.
- [WOL2008] Wolfesperger, H. A.: Elektromagnetische Schirmung. Theorie und Praxisbeispiele. Springer Berlin Heidelberg, Berlin, Heidelberg, 2008.
- [WOL2015] Wolff, G. K.: Erdung - (K)ein Buch mit sieben Siegeln, Blomberg, 2015.

10 Appendix A1 Current Clamp Recommendations

The current clamp used for shield current measurements should meet the following requirements:

- Frequency range at least up to 1...2 kHz or higher
- Measurement of direct current and alternating current (two devices if necessary)
- Leakage current measurement as an additional function should be possible
- Measuring range 1 10 μ A... 40 mA , measuring range 2 up to 400 mA
- Possibly detection breakage cable shield

© Copyright by

PROFIBUS Nutzerorganisation e. V. (PNO)
PROFIBUS & PROFINET International (PI)
Haid-und-Neu-Str. 7 • 76131 Karlsruhe • Germany
Phone +49 721 986 197 0 • Fax +49 721 986 197 11
E-mail info@profibus.com
www.profibus.com • www.profinet.com
